

NB 2163

EU TYPE EXAMINATION CERTIFICATE

Certificate No: 2163-PPE-1795

Respiratory protective devices, filtering half masks to protect against particles manufactured by

PASHA HOME ITH. IHR. LTD. ŞTİ.

are tested and evaluated according to

EN 149:2001 + A1:2009 Respiratory Protective Devices -Filtering
Half Masks to Protect Against Particles - Requirements,
Testing, Marking

Based on the type examination conducted with the evaluation of test reports, technical file according to Personal Protective Equipment Regulation (EU) 2016/425 Annex 5, it is approved that the product meets the requirements of the regulation.

Product Definition

Single use particle filtering half mask for protection against solid and liquid aerosols, is a folding type, 5 layered, without valve, ear straps and adjustable nose bar.

Brand Name: Pasha Home

Model: PSH-NRFM001

Classification: FFP2 NR

Here by the manufacturer is allowed to use notified body number (2163) and can fix CE mark, as shown below, on the Category III product models given above, with;

-Issuing an appropriate EU Declaration of Conformity according to **Personal Protective Equipment Regulation (EU) 2016/425 Annex 9.**

-Ongoing successful performance in fulfilment of the requirements set out in Personal Protective Equipment Regulation (EU) 2016/425 and harmonized standards, ensured by assessments based on **Annex 7 (Module C2) or Annex 8 (Module D)** of the regulation no later than 1 year from the beginning of serial production

This certificate is initially issued on **16/12/2020** and will be valid for 5 years, if there is no change in the relevant harmonized standard affecting the essential health and safety requirements.



A blue ink handwritten signature, which appears to read 'Oktay Ersoy', is placed over a light blue rectangular background.

Director

TECHNICAL ASSESSMENT REPORT

REPORT DATE / NO: 15.12.2020 / 2163-KKD-1795

Manufacturer: PASHA HOME ITH. IHR. LTD. ŞTİ.

Address: Mahmutbey Mah. Istoc 1. Ada No: 154-156 Bagcilar / Istanbul TURKEY

Introduction

This report is for the, given above, manufacturer prepared according to the test results obtained from ANHUI HONREN GROUP CO LTD, dated 13.12.2020 with Serial Id 12-2020-T0575 based on EN 149: 2001 + A1 : 2009 standard and the technical file dated 25 October 2020 (Revision 00) provided by the manufacturer.

The technical file of the manufacturer, and risk evaluation against the essential health safety requirements and the test report evaluated for their relation with Essential Requirements of Personel Protective Equipment Regulation and found to be appropriate.

This report is an annex and an integral part of the EU Type Examination Certificate issued to the manufacturer. The test results and issued certificate belongs only to the tested model. The technical report consists of a total of 6 pages.

Product Description: Single use particle filtering half mask for protection against solid and liquid aerosols, is a folding type, 5 layered, without valve, ear straps and adjustable nose bar.

Component and Materials:

Component	Materia I	Grade
Outer Layer	Spunbond fabric	50 g/m2
Filter Layer I	Hot air cotton fabric	60 g/m
Filter Layer II	Melt-blown fabric	25 g/m
Inner Layer	Spunbond fabric	30 g/m
Ear Strap	Spandex + Nylon	Width 5+-1 mm Length: 200+20 mm
Nose Bridge	Polypropylene + Galvanized iron wire	Width 5+-1 mm Diameter: 0,5 +/-0,02 mm

Classification: FFP2 NR

Brand name: Pasha Home **Model:** PSH-NRFM001



ESSENTIAL HEALTH and
SAFETY
REQUIREMENTS GIVEN IN EUROPEAN UNION REGULATION EU 2016/425 CORRESPONDING RISKS FOR THE
PRODUCT

1.1. Design principles

1.1.1. Ergonomics

PPE must be so designed and manufactured that in the foreseeable conditions of use for which it is intended the user can perform the risk related activity normally whilst enjoying appropriate protection of the highest possible level.

1.1.2. Levels and classes of protection

1.1.2.1. Highest level of protection possible

The optimum level of protection to be taken into account in the design is that beyond which the constraints by the wearing of the PPE would prevent its effective use during the period of exposure to the risk or normal performance of the activity.

1.1.2.2. Classes of protection appropriate to different levels of risk

Where differing foreseeable conditions of use are such that several levels of the same risk can be distinguished, appropriate classes of protection must be taken into account in the design of the PPE.

1.2. Innocuousness of PPE

1.2.1. Absence of risks and other inherent nuisance factors

PPE must be so designed and manufactured as to preclude risks and other nuisance factors under foreseeable conditions of use.

1.2.1.1. Suitable constituent materials

The materials of which the PPE is made, including any of their possible decomposition products, must not adversely affect the health or safety of users.

1.2.1.2. Satisfactory surface condition of all PPE parts in contact with the user

Any part of the PPE that is in contact or is liable to come into contact with the user when the PPE is worn must be free of rough surfaces, sharp edges, sharp points and the like which could cause excessive irritation or injuries

1.2.1.3. Maximum permissible user impedance

Any impediment caused by PPE to movements to be made, postures to be adopted and sensory perception must be minimized; nor must PPE cause movements which endanger the user or other persons.

1.3. Comfort and effectiveness

1.3.1. Adaptation of PPE to user morphology

PPE must be designed and manufactured in such a way as to facilitate its correct positioning on the user and to remain in place for the foreseeable period of use, bearing in mind ambient factors, the actions to be carried out and the postures to be adopted. For this purpose, it must be possible to adapt the PPE to fit the morphology of the user by all appropriate means, such as adequate adjustment and attachment systems or the provision of an adequate range of sizes.

1.3.2. Lightness and design strength

PPE must be as light as possible without prejudicing design strength and efficiency.

Apart from the specific additional requirements which they must satisfy in order to provide adequate protection against the risks in question (see 3), PPE must be capable of withstanding the effects of ambient phenomena inherent under the foreseeable conditions of use

1.4. Information supplied by the manufacturer

The notes that must be drawn up by the former and supplied when PPE is placed on the market must contain all relevant information on:

- a) In addition to the name and address of the manufacturer and/or his authorized representative established in the Community
- b) Storage, use, cleaning, maintenance, servicing and disinfection. cleaning, maintenance or disinfectant protection recommended by manufacturers must have no adverse effect on PPE or users when applied in accordance with the relevant instructions;
- c) Performance as recorded during technical tests to check the levels or classes of protection provided by the PPE in question;
- d) Suitable PPE accessories and the characteristics of appropriate spare parts;
- e) The classes of protection appropriate to different levels of risk and the corresponding limits of use;
- f) The obsolescence deadline or period of obsolescence of PPE or certain of its components;
- g) The type of packaging suitable for transport;
- h) The significance of any markings(see 2.12)
- i) Where appropriate the references of the Directives applied in accordance with Article5(6) (b);
- j) The name, address and identification number of the notified body involved in the design stage of the PPE

These notes, which must be precise and comprehensible, must be provided at least in the official language(s) of the member state of destination



2. ADDITIONAL REQUIREMENTS COMMON TO SEVERAL CLASSES OR TYPES OF PPE

2.1. PPE incorporating adjustment systems

If PPE incorporates adjustment systems, the latter must be designed and manufactured so that, after adjustment, they do not become undone unintentionally in the foreseeable conditions of use.

2.3. PPE for the face, eyes and respiratory system

Any restriction of the user's face, eyes, field of vision or respiratory system by the PPE shall be minimized.

The screens for those types of PPE must have a degree of optical neutrality that is compatible with the degree of precision and the duration of the activities of the user.

If necessary, such PPE must be treated or provided with means to prevent misting-up.

Models of PPE intended for users requiring sight correction must be compatible with the wearing of spectacles or contact lenses.

2.4. PPE subject to ageing

If it is known that the design performance of new PPE may be significantly affected by ageing, the month and year of manufacture and/or, if possible, the month and year of obsolescence must be indelibly and unambiguously marked on each item of PPE placed on the market and on its packaging.

If the manufacturer is unable to give an undertaking with regard to the useful life of the PPE, his instructions must provide all the information necessary to enable the purchaser or user to establish a reasonable obsolescence month and year, taking into account the quality level of the model and the effective conditions of storage, use, cleaning, servicing and maintenance.

Where appreciable and rapid deterioration in PPE performance is likely to be caused by ageing resulting from the periodic use of a cleaning process recommended by the manufacturer, the latter must if possible, affix a marking to each item of PPE placed on the market indicating the maximum number of cleaning operations that may be carried out before the equipment needs to be inspected or discarded. Where such a marking is not affixed, the manufacturer must give that information in his instructions.

2.6. PPE for use in potentially explosive atmospheres

PPE intended for use in potentially explosive atmospheres must be designed and manufactured in such a way that it cannot be the source of an electric, electrostatic or impact-induced arc or spark likely to cause an explosive mixture to ignite.

2.8. PPE for intervention in very dangerous situations

The instructions supplied by the manufacturer with PPE for intervention in very dangerous situations must include, in particular, data intended for competent, trained persons who are qualified to interpret them and ensure their application by the user.

The instructions must also describe the procedure to be adopted in order to verify that PPE is correctly adjusted and functional when worn by the user. Where PPE incorporates an alarm which is activated in the absence of the level of protection normally provided, the alarm must be designed and placed so that it can be perceived by the user in the foreseeable conditions of use.

2.9. PPE incorporating components which can be adjusted or removed by the user

Where PPE incorporates components which can be attached, adjusted or removed by the user for replacement purposes, such components must be designed and manufactured so that they can be easily attached, adjusted and removed without tools.

2.12. PPE bearing one or more identification or recognition marks directly or indirectly relating to health and safety

The identification or recognition marks directly or indirectly relating to health and safety affixed to these types or classes of must preferably take the form of harmonized pictograms or ideograms and must remain perfectly legible throughout the foreseeable useful life of the PPE. In addition, these marks must be complete, precise and comprehensible so as to prevent any misinterpretation: in particular, where such marks incorporate words or sentences, the latter must appear in the official language(s) of the Member State where the equipment is to be used.

If PPE (or a PPE component) is too small to allow all for part of the necessary marking to be affixed, the relevant information must be mentioned on the packing and in the manufacturer's notes.

3. ADDITIONAL REQUIREMENTS SPECIFIC TO PARTICULAR RISKS

3.10.1. Respiratory protection

PPE intended for the protection of the respiratory system must make it possible to supply the user with breathable air when exposed to a polluted atmosphere and/or an atmosphere having an inadequate oxygen concentration.

The breathable air supplied to the user by PPE must be obtained by appropriate means, for example after filtration of the polluted air through PPE or by supply from an external unpolluted source.

The constituent materials and other components of those types of PPE must be chosen or designed and incorporated so as to ensure appropriate user respiration and respiratory hygiene for the period of wear concerned under the foreseeable conditions of use.

The leak-tightness of the facepiece and the pressure drop on inspiration and in the case of the filtering devices, purification capacity must keep contaminant penetration from a polluted atmosphere low enough not to be prejudicial to the health or hygiene of the user.

The PPE must bear details of the specific characteristics of the equipment which, in conjunction with the instructions, enable a trained and qualified user to employ the PPE correctly.

In the case of filtering equipment, the manufacturer's instructions must also indicate the time limit for the storage of new original packaging.



Technical Assessment of EN 149: 2001 + A1 : 2009 Standard and other Standards it refers to, Clauses Corresponding to the (EU) 2016/425 Directive

Conforming to EN 149:2001 + A1:2009 Standard Requirements			
Article 5	Classification: Particle Filtering Half Mask The mask subject to evaluation based on the test results and technical file provided by the manufacturer is classified as: Filtering Efficiency and Maximum Total Inward Leakage- Classified as FFP2 Mask is classified for single shift use NR		
Article 7.4	Packaging: Particle filtering half masks are packaged to protect them from contamination before use and with cardboard boxes to prevent mechanical damage. The packaging design and the product is considered to withstand the foreseeable conditions of use based on the visual inspection results given in the test report.		
Article 7.5	Material: Materials used in particle filtering half masks, according to the simulated wearing treatment and temperature conditioning results; It is understood it withstands handling and wear over the period for which the particle filtering half mask is designed to be used, it suffered mechanical failure of the facepiece or straps, any material from the filter media is released by the air flow through the filter has not constitute a hazard or nuisance for the wearer. The manufacturer declares that the materials used in manufacturing of the mask does not have an adverse affect to the health and safety of users. Based on the test result, the masks did not collapse when subject to simulated wearing and temperature conditioning. No nuisance situation is reported during the practical performance tests by human subjects.		
Article 7.6	Cleaning and disinfection: Particle filtering half mask is not designed to be as re-usable. No cleaning or disinfection procedure provided by the manufacturer.		
Article 7.7	Practical Performance: The test report indicates that the human subjects did not face any difficulty in performing the exercises while they were weared by the sample masks, in walking test or work simulation tests. The wearers did not report any failure by means of head harness / straps/ ear loops comfort. security of fastenings and field of vision. Also, no imperfections reported during total inward tests about the comfort, field of vision and fastening issues.		
	Assessed Elements	Positive	Negative
	Requirements in accordance with EN 149:2001 + A1:2009 and Result		
	2. Head harness comfort	2	0
	3. Security of fastenings	2	0
	5. Field of vision	2	0
	Conditioning: (A.R.) As Received, original		
	Positive results are obtained from the test subjects No imperfections		

Article 7.8	Finish of Parts: Particle filtering half masks, which are likely to come into contact with the user do not have sharp edges and do not contain burrs.																																									
Article 7.9.1	<p>Total Inward Leakage:</p> <p>The Total Inward Leakage test is conducted by 10 individual in an aerosol chamber with a walking band, and samples are taken during the conduction of the exercises defined in the standard. The samples used in the test are subjected to the conditioning required in the standard as temperature conditioning, and as received. The face dimensions of the subjects are also reported. The measurement details for each subject and for each exercise are available in tire test report.</p> <p>It was reported that:</p> <p>All 50 exercise measurement results are smaller or equal to 11% the values varies between 7,23% and 7,98%.</p> <p>All 10 individual's arithmetic mean is smaller or equal to 8% the values varies between 7,58% and 7,72%.</p>																																									
Article 7.9.2.	<p>According to the reported results, the product meets the limits for FFP2 classification.</p> <table border="1"> <thead> <tr> <th colspan="5">Penetration of filter material: Sodium Chloride Testing</th> </tr> <tr> <th>Condition</th> <th>No. of Sample</th> <th>Sodium Chloride Testing 95L/min max (%)</th> <th>Requirements in accordance with EN 149: 2001 +A1:2009</th> <th>Results</th> </tr> </thead> <tbody> <tr> <td>(A.R.)</td> <td>36</td> <td>0,86</td> <td rowspan="8">FFP1≤ 20% FFP2≤ 6% FFP3≤ 1%</td> <td rowspan="8">Filtering half masks fulfill the requirements of the standard EN 149:2001 + A1:2009 given in 7.9.2 in range of the FFP1 and FFP2 classes.</td> </tr> <tr> <td>(A.R.)</td> <td>37</td> <td>1,05</td> </tr> <tr> <td>(A.R.)</td> <td>38</td> <td>0,95</td> </tr> <tr> <td>(S.W.)</td> <td>1</td> <td>0,99</td> </tr> <tr> <td>(S.W.)</td> <td>2</td> <td>1,01</td> </tr> <tr> <td>(S.W.)</td> <td>3</td> <td>1,03</td> </tr> <tr> <td>(M.S.T.C.)</td> <td>10</td> <td>0,98</td> </tr> <tr> <td>(M.S.T.C.)</td> <td>11</td> <td>0,96</td> </tr> <tr> <td>(M.S.T.C.)</td> <td>12</td> <td>0,90</td> <td></td> <td></td> </tr> </tbody> </table> <p>Conditioning: (M.S) Mechanical Strength (T.C.) Temperature conditioning (A.R.) As received, original (S.W.) Simulated wearing treatment</p> 	Penetration of filter material: Sodium Chloride Testing					Condition	No. of Sample	Sodium Chloride Testing 95L/min max (%)	Requirements in accordance with EN 149: 2001 +A1:2009	Results	(A.R.)	36	0,86	FFP1≤ 20% FFP2≤ 6% FFP3≤ 1%	Filtering half masks fulfill the requirements of the standard EN 149:2001 + A1:2009 given in 7.9.2 in range of the FFP1 and FFP2 classes.	(A.R.)	37	1,05	(A.R.)	38	0,95	(S.W.)	1	0,99	(S.W.)	2	1,01	(S.W.)	3	1,03	(M.S.T.C.)	10	0,98	(M.S.T.C.)	11	0,96	(M.S.T.C.)	12	0,90		
Penetration of filter material: Sodium Chloride Testing																																										
Condition	No. of Sample	Sodium Chloride Testing 95L/min max (%)	Requirements in accordance with EN 149: 2001 +A1:2009	Results																																						
(A.R.)	36	0,86	FFP1≤ 20% FFP2≤ 6% FFP3≤ 1%	Filtering half masks fulfill the requirements of the standard EN 149:2001 + A1:2009 given in 7.9.2 in range of the FFP1 and FFP2 classes.																																						
(A.R.)	37	1,05																																								
(A.R.)	38	0,95																																								
(S.W.)	1	0,99																																								
(S.W.)	2	1,01																																								
(S.W.)	3	1,03																																								
(M.S.T.C.)	10	0,98																																								
(M.S.T.C.)	11	0,96																																								
(M.S.T.C.)	12	0,90																																								
Article 7.9.2	<table border="1"> <thead> <tr> <th colspan="5">Penetration of filter material: Paraffin Oil testing</th> </tr> <tr> <th>Condition</th> <th>No. of Sample</th> <th>Paraffin oil Testing 95L/min max (%)</th> <th>Requirements in accordance with EN 149: 2001 +A1:2009</th> <th>Results</th> </tr> </thead> <tbody> <tr> <td>(A.R.)</td> <td>39</td> <td>1,88</td> <td rowspan="10">FFP1≤ 20% FFP2≤ 6% FFP3≤ 1%</td> <td rowspan="10">Filtering half masks fulfill the requirements of the standard EN 149:2001 + A1:2009 given in 7.9.2. in range of the FFP1 and FFP2 classes.</td> </tr> <tr> <td>(A.R.)</td> <td>40</td> <td>2,03</td> </tr> <tr> <td>(A.R.)</td> <td>41</td> <td>1,93</td> </tr> <tr> <td>(S.W.)</td> <td>4</td> <td>1,95</td> </tr> <tr> <td>(S.W.)</td> <td>5</td> <td>1,99</td> </tr> <tr> <td>(S.W.)</td> <td>6</td> <td>1,96</td> </tr> <tr> <td>(M.S.T.C.)</td> <td>13</td> <td>1,97</td> </tr> <tr> <td>(M.S.T.C.)</td> <td>14</td> <td>2,01</td> </tr> <tr> <td>(M.S.T.C.)</td> <td>15</td> <td>1,99</td> </tr> </tbody> </table> <p>Conditioning: (M.S) Mechanical Strength (T.C.) Temperature conditioning (A.R.) As received, original (S.W.) Simulated wearing treatment</p>	Penetration of filter material: Paraffin Oil testing					Condition	No. of Sample	Paraffin oil Testing 95L/min max (%)	Requirements in accordance with EN 149: 2001 +A1:2009	Results	(A.R.)	39	1,88	FFP1≤ 20% FFP2≤ 6% FFP3≤ 1%	Filtering half masks fulfill the requirements of the standard EN 149:2001 + A1:2009 given in 7.9.2. in range of the FFP1 and FFP2 classes.	(A.R.)	40	2,03	(A.R.)	41	1,93	(S.W.)	4	1,95	(S.W.)	5	1,99	(S.W.)	6	1,96	(M.S.T.C.)	13	1,97	(M.S.T.C.)	14	2,01	(M.S.T.C.)	15	1,99		
Penetration of filter material: Paraffin Oil testing																																										
Condition	No. of Sample	Paraffin oil Testing 95L/min max (%)	Requirements in accordance with EN 149: 2001 +A1:2009	Results																																						
(A.R.)	39	1,88	FFP1≤ 20% FFP2≤ 6% FFP3≤ 1%	Filtering half masks fulfill the requirements of the standard EN 149:2001 + A1:2009 given in 7.9.2. in range of the FFP1 and FFP2 classes.																																						
(A.R.)	40	2,03																																								
(A.R.)	41	1,93																																								
(S.W.)	4	1,95																																								
(S.W.)	5	1,99																																								
(S.W.)	6	1,96																																								
(M.S.T.C.)	13	1,97																																								
(M.S.T.C.)	14	2,01																																								
(M.S.T.C.)	15	1,99																																								
Article 7.10	Compatibility with skin: In Practical Performance report, the likelihood of mask materials in contact with the skin causing irritation or other adverse effect on health was not reported.																																									
Article 7.11	<p>Flammability</p> <table border="1"> <thead> <tr> <th>Condition</th> <th>No. of Sample</th> <th>Visual inspection</th> <th>Requirements in accordance with EN 149: 2001 +A1:2009</th> <th>Result</th> </tr> </thead> <tbody> <tr> <td>(A.R.)</td> <td>45</td> <td>Burn for 0,0s</td> <td rowspan="4">Filtering half mask shall not burn or not continue to burn for more than 5 s after removal from the flame</td> <td rowspan="4">Passed Filtering half masks fulfill requirements of the standard</td> </tr> <tr> <td>(A.R.)</td> <td>46</td> <td>Burn for 0,0s</td> </tr> <tr> <td>(T.C.)</td> <td>21</td> <td>Burn for 0,0s</td> </tr> <tr> <td>(T.C.)</td> <td>22</td> <td>Burn for 0,1s</td> </tr> </tbody> </table> <p>Conditioning: (A.R.) As received, original (T.C.) Temperature conditioning</p>	Condition	No. of Sample	Visual inspection	Requirements in accordance with EN 149: 2001 +A1:2009	Result	(A.R.)	45	Burn for 0,0s	Filtering half mask shall not burn or not continue to burn for more than 5 s after removal from the flame	Passed Filtering half masks fulfill requirements of the standard	(A.R.)	46	Burn for 0,0s	(T.C.)	21	Burn for 0,0s	(T.C.)	22	Burn for 0,1s																						
Condition	No. of Sample	Visual inspection	Requirements in accordance with EN 149: 2001 +A1:2009	Result																																						
(A.R.)	45	Burn for 0,0s	Filtering half mask shall not burn or not continue to burn for more than 5 s after removal from the flame	Passed Filtering half masks fulfill requirements of the standard																																						
(A.R.)	46	Burn for 0,0s																																								
(T.C.)	21	Burn for 0,0s																																								
(T.C.)	22	Burn for 0,1s																																								
Article 7.12	<p>Carbon dioxide content of the inhalation air:</p> <table border="1"> <thead> <tr> <th>Condition</th> <th>No. of sample</th> <th>CO2 content of the inhalation air (%) by volume</th> <th>An average CO2 content of the inhalation air</th> <th>Requirements in accordance with EN 149: 2001 +A1:2009</th> <th>Result</th> </tr> </thead> <tbody> <tr> <td>(A.R.)</td> <td>26</td> <td>0,45</td> <td rowspan="3">0,48 (%)</td> <td rowspan="3">CO2 content of the inhalation air shall not exceed an average of 1,0% by volume</td> <td rowspan="3">Passed Filtering half masks fulfil requirements of the standard</td> </tr> <tr> <td>(A.R.)</td> <td>27</td> <td>0,52</td> </tr> <tr> <td>(A.R.)</td> <td>28</td> <td>0,47</td> </tr> </tbody> </table> <p>Conditioning: (A.R.) As received, original</p>	Condition	No. of sample	CO2 content of the inhalation air (%) by volume	An average CO2 content of the inhalation air	Requirements in accordance with EN 149: 2001 +A1:2009	Result	(A.R.)	26	0,45	0,48 (%)	CO2 content of the inhalation air shall not exceed an average of 1,0% by volume	Passed Filtering half masks fulfil requirements of the standard	(A.R.)	27	0,52	(A.R.)	28	0,47																							
Condition	No. of sample	CO2 content of the inhalation air (%) by volume	An average CO2 content of the inhalation air	Requirements in accordance with EN 149: 2001 +A1:2009	Result																																					
(A.R.)	26	0,45	0,48 (%)	CO2 content of the inhalation air shall not exceed an average of 1,0% by volume	Passed Filtering half masks fulfil requirements of the standard																																					
(A.R.)	27	0,52																																								
(A.R.)	28	0,47																																								

Article 7.13	Head harness: In Practical Performance and TIL test reports no adverse effects have been reported for donning and remove of the mask also the results of these tests indicates that the ear loops / head harness are capable of holding the mask firmly enough.
Article 7.14	Field of vision: In Practical Performance report, no adverse effects were reported for the field of vision availability when the mask is weared.
Article 7.15	Exhalation Valve(s): The model under inspection have no valves. Passed.
Article 7.16	Breathing Resistance: inhalation The overall evaluation in the figures gathered for 9 different samples 3 as received. 3 with temperature conditioning and 3 simulated wearing treatment conditioned complies with the limits given in the standard for FFP1, FFP2 and PFP3 classes. This is valid for inhalation results for 30 L/min, 95 L/min and exhalation at 160 L/min. Passed.



Article 7.17	Clogging: This test is not applied to Particle Filtering Half Mask which is not reusable. (For single shift use devices, the clogging test is optional test. For re-usable devices test is mandatory.)
Article 7.18	Demountable Parts: There are no demountable parts on the product.
Article 8	Testing: All tests conducted according to Clause 8 of this standard is available in the test report and are evaluated in this report for qualification and classification of the mask.
Article 9	Marking – Packaging: Necessary markings are available on the product package (box). The name and trademark of the manufacturer is clearly visible. The type of the mask and the classification including the status of re-usability, the reference to EN 149:2001+A1:2009 standard, the year of end of shelf life, using and storage instructions and pictograms and CE mark are available on the product package. The above evaluation is based on the technical document for packaging and marking, for box design. Verified Section 9.1 on the technical file. The technical documentation for mask design (drawing) also evaluated for marking requirements, drawing PSH-NRFM001. The mask marking indicates that the mask will carry information about the brandname (Pasha Home) of the manufacturer, type of mask, the reference to EN 149+A1:2009 standard and classification including the re-usability of the mask. The manufacturer also printed CE mark with our Notified Body number. The mask do not have sub-assemblies. The tested samples by the laboratory carry necessary marking information as stated in the technical documentation. the manufacturer shall also follow marking instruction in the technical file for serial production. Model PSH-NRFM001 drawing exists in the technical file Section 6 of the manufacturer.
Article 10	Information to be supplied by the manufacturer: In each of the smallest commercially available packaging of the product, implementation (installation instructions) pre-use controls, warning and usage limitations, storage and meanings of symbols / pictograms are defined. User instruction document in the technical file Section 8 found to be appropriate. The manufacturer shaft include this documented user information text in every smallest commercially available package.

PREPARED BY	APPROVED BY
 PPE Expert	 Director

ANHUI HONREN GROUP CO LTD
Xingyuan East Road, Economic Development Zone, Anhui, China

TEST REPORT

Report Date: 13.12.2020
Report Number: 12-2020-T0575

CLIENT AND SAMPLE INFORMATION

TEST OWNER	PASHA HOME ITH. IHR. LTD. STI		
ADDRESS	Mahmutbey Mah. Istoc 1 Ada No: 154-156 Bagcilar / Istanbul TURKEY		
SAMPLE DESCRIPTION	Folding type protective mask		
BRAND NAME - MODEL	PASHA HOME / PSH-NRFM001		
TESTING STANDARD	EN 149:2001+A1:2009		
CASE NUMBER	CE-PPE-3749		
SAMPLE RECEIVE DATE	23.11.2020	TESTING START DATE	23.11.2020
DISINFECTION	Not given, single use only		
INSTRUCTION if applicable			
NUMBER OF SAMPLES	50	SAMPLE IDs:	1-46
AS RECEIVED SAMPLE NO	26-46		
CONDITIONING SAMLE NO	Simulated wearing treatment	1-2-3-4-5-6-7-8-9 (As received)	
	Temperature conditioning	10-11-12-13-14-15 (sample after test of mechanical strength)	
		16-17-18-19-20-21-22-23-24-25 (as received)	
	Mechanical strength	10-11-12-13-14-15 (as received)	

The results given in this test report belongs to the samples tested. The report content cannot be recreated partially without the written consent of ANHUI HONREN GROUP CO LTD



UNIVERSAL
SERTİFİKASYON
VE GÖZLEME HİZM.
TİC. LTD. STİ.
Necip Fazıl Bulvarı, Kevap Sitesi, E2 Blok No:44/84
Yukarı Dudullu-Ümraniye/İSTANBUL
Telefon: 0216 455 80 80 Faks: 0216 455 80 08
Sarıgazi V.D. 892 025 8722

Suat KAÇMAZ
Director

1. REPORT SUMMARY

TEST STANDARD	TESTNAME	RESULT	EVALUATION
EN 149:2001 + Al:2009 clause 8.5 EN 13274-1:2001	Total Inward Leakage Testing	Pass	FFP2
EN 149:2001 + Al:2009 clause 8.11 EN 13274-7:2019	Penetration of Filter Material	Pass	FFP2
EN 149:2001 + Al:2009 clause 8.6 EN 13274-4:2001	Flammability Testing	Pass	See results
EN 149:2001 + Al:2009 clause 8.7 EN 13274-6:2001	Carbon Dioxide Content of The Inhalation Air Testing	Pas	See results
EN 149:2001 + Al:2009 clause 8.9 EN 13274-3:2001	Breathing Inhalation Resistance-30 1/min	Pass	See results
	Breathing Inhalation Resistance-95 1/min	Pass	See results
EN 149:2001 + Al:2009 clause 8.9 EN 13274-3:2001	Exhalation Resistance, flow rate 160 1/min	Pass	See results



UNIVERSAL
SERTİFİKASYON
VE GÖZETİM HİZİVİ
TIC. LTD. STI.
İp: Eski Büyükköy Mah. Şehir E2 Blok, no: 11/8
Yukarı Dündarlı Mah. İst. 411 BİJL
Telefon: 0216 455 90 80 Faks: 0216 455 30 00
Sarrazı V.D. 892 025 9722

2. TEST RESULTS AND EVALUATION

7.4 PACKAGING (EN 149:2001 + A1:2009 clause 8.2)

Test Method: Clause 8.2-Visual inspection

REQUIREMENTS	RESULTS	COMMENT
Particle filtering half masks shall be offered for sale packaged in such a way that they are protected against mechanical damage and contamination before use.	Pass	The masks were packed in sealed plastic bags, in larger plastic bags inside a large cardboard box that gave some protection against mechanical damage or contamination before use.

Lab A

7.5 MATERIAL (EN 149:2041 + A1:2009 clause 8.2, 8.3.1, 8.3.2)

Test Method: Clause 8.2-Visual inspection

Clause 8.3.1-Simulated wearing treatment

A breathing machine is adjusted to 25 cycles/min and 2,0 l/stroke. The particle filtering half mask was mounted on a Sheffield dummy head.

For testing, a saturator is incorporated in the exhalation line between the breathing machine and the dummy head, the saturator being set at a temperature in excess of 37 °C to allow for the cooling of the air before it reaches the mouth of the dummy head.

The air has been saturated at (37 + 2) °C at the mouth of the dummy head

Clause 8.3.2-Temperature conditioning

The ambient temperature for testing has been between 16 °C and 32 °C and the temperature limits has been subject to an accuracy of ± 1 °C.

a) for 24 h to a dry atmosphere of (70 + 3) °C;

b) for 24 h to a temperature of (-30 + 3) °C; and allow to return to room temperature for at least 4 h between exposures and prior to subsequent testing. The conditioning has been carried out in a manner which ensures that no thermal shock occurs.

REQUIREMENT	RESULTS	COMMENT
Material used shall be suitable to withstand handling and wear over the period for which the particle filtering half mask is designed to be used.	Pass	The material used were able to withstand handling and wear during the limited laboratory testing carried out.
Any material from the filter media released by the air flow through the filter shall not constitute a hazard or nuisance for the wearer.	Pass	It was not constitute a hazard or nuisance for the wearer.
After undergoing the conditioning described in 8.3.1. none of the particle filtering half masks shall have suffered mechanical failure of the facepiece or straps.	Pass	None of the specimens conditioned suffered mechanical failure.
When conditioned in accordance with 8.3.1. and 8.3.2. the particle filtering half mask shall not collapse.	Pass	None of the specimens had not collapse after conditioning.

Lab B

7.6. CLEANING AND DISINFECTING (EN 149:2001 + A1:2009 clause 8.4, 8.5, 8.11)

<u>REQUIREMENT</u>	<u>RESULTS</u>	<u>COMMENT</u>
If the particle filtering half mask is designed to be re-usable, the materials used shall withstand the cleaning and disinfecting agents and procedures to be specified by the manufacturer. With reference to 7.9.2, after cleaning and disinfecting the re-usable particle filtering half mask shall satisfy the penetration requirement of the relevant class.	N/A	This article is not applicable for tested protective mask which is single use disposable mask.

Test Method: Described in Clause 8.4, 8.5 and 8.11

7.7. PRACTICAL PERFORMANCE (EN 149:2001 + A1:2009 clause 8.4)

Test Method: Described in Clause 8.4

<u>REQUIREMENT</u>	<u>RESULTS</u>	<u>COMMENT</u>
The particle filtering half mask shall undergo practical performance tests under realistic conditions. These general tests serve the purpose of checking the equipment for imperfections that can not be determined by the tests described elsewhere in this standard. Two as received mask samples are used by two subject for the walking (10 mins walking with a speed of 6km/h) and work simulation (bended walking, crawling and basket filling exercises) tests.	No imperfections	Detail refer to Annex I

Annex I-Test Result:

Assessed elements	Positive Assessment	Negative Assessment	Requirements in accordance with EN 149:2001+A1:2009	Assessment of Test Result Conformity / Nonconformity
The face piece fitting Head harness comfort Security of fastenings Field of vision	2 2 2	0 0 0	Filtering half masks should not have imperfections related to wearer's acceptance	Filtering half masks fulfil requirements of the standard EN 149:2001 + A1:2009 given in 7.7 No imperfections

Number of sample: 29 (A.R), 30 (A.R)

The subjects (MEG and MA) were able to complete the exercises and did not report any nuisance or problem with the mask.

7.8. FINISH OF PARTS (EN 149:2001 + A1:2009 clause 8.2)

Test Method: Described in Clause 8.2

<u>REQUIREMENT</u>	<u>RESULTS</u>	<u>COMMENT</u>
Parts of the device likely to come into contact with the wearer shall have no sharp edges or burrs.	Pass	None of the specimens used in laboratory testing showed evidence of sharp edges or burrs while visual inspection and performance tests.

7.9.1 TOTAL INWARD LEAKAGE (EN 149:2001 + A1:2009 clause 8.5)

Test Method: Described in Clause 8.5

REQUIREMENT	RESULTS	COMMENT
The total inward leakage consists of three components: face seal leakage, exhalation valve leakage (if exhalation valve fitted) and filter penetration. For particle filtering half masks fitted in accordance with the manufacturer's information, at least 46 out of the 50 individual results shall be not greater than: 25 % for FFP1, 11 % for FFP2, 5 % for FFP3 and in addition at least 8 out of the 10 individual wearer arithmetic means for the total inward leakage shall not be greater than: 22 % for FFP1, 8 % for FFP2, 2 % for FFP3	Pass	Classified as FFP2 Detail refer to Annex II

Annex II-Test Result:

The test results obtained are given in the tables as follows

Test Subject	No of sample	Cond.	1. Walk (%)	Head side/side (%)	Head up/down (%)	Talk (%)	2. Walk (%)	Average (%)
1	31	A.R.	7,23	7,41	7,62	7,77	7,89	7,58
2	32	A.R.	7,31	7,52	7,69	7,79	7,96	7,65
3	33	A.R.	7,33	7,54	7,72	7,85	7,94	7,67
4	34	A.R.	7,35	7,55	7,71	7,82	7,93	7,67
5	35	A.R.	7,29	7,53	7,75	7,86	7,91	7,66
6	16	T.C.	7,34	7,60	7,71	7,84	7,95	7,68
7	17	T.C.	7,33	7,57	7,69	7,81	7,97	7,67
8	18	T.C.	7,31	7,60	7,72	7,83	7,95	7,68
9	19	T.C.	7,38	7,62	7,75	7,89	7,98	7,72
10	20	T.C.	7,34	7,63	7,72	7,85	7,92	7,69

All 50 individual exercise results were not greater than 11 %
All 10 individual wearer arithmetic means were not greater than 8 %.

Pass (FFP2)

Test Subject	Face Length (mm)	Face Width (mm)	Face Depth (mm)	Mouth Width (mm)
1	117	155	130	60
2	113	148	128	62
3	112	160	134	59
4	115	148	125	61
5	120	158	132	57
6	118	150	134	59
7	115	152	130	57
8	117	155	134	59
9	114	149	128	57
10	110	150	131	55

For Information Only



UNIVERSAL
SERTİFİKASYON
VE GÖZETİM HİZM.
TSC. LTD. STL.
Eskişehir, Kocatepe Mah. E2 Blok, h/o:4z/8a
Yıldız Demir Uzunlu Mah. 15. Sokak No: 15/1
Tel: 0216 455 80 80 Fax: 0216 455 00 08
Samsun V.D. 892 025 8722

7.9.2 PENETRATION OF FILTER MATERIAL (EN 149:2001 + A1:2009 clause 8.11)

Test Method: Described in Clause 8.11

REQUIREMENT			RESULTS	COMMENT
Classification	Max penetration of test aerosol NaCl test 95 l/min % max	Paraffin oil test 95 l/min % max	Pass	Detail refer to Annex IIIA and IIIB
FFP1	20	20		
FFP2	6	6		
FFP3	1	1		

Annex IIIA – Test Result:

The test results obtained are given in the tables as follows:

No. of sample	Condition	Penetration of Sodium Chloride in accordance with EU 13274-7:2019 (%) Flow rate 95 l/min	Requirements in accordance with EN 149:2001 + A1:2009	Assessment of Test Result Conformity / Nonconformity
36	As received	0,86	FFP1≤ 20% FFP2≤ 6% FFP3≤ 1%	Passed Filtering half masks fulfill the requirements of the standard EN 149:2001+A1:2009 given in 7.9.2. in range of the first and second protection class (FFP1,FFP2)
37		1,05		
38		0,95		
1	Simulated wearing treatment	0,99	FFP2≤ 6% FFP3≤ 1%	Passed Filtering half masks fulfill the requirements of the standard EN 149:2001+A1:2009 given in 7.9.2. in range of the first and second protection class (FFP1,FFP2)
2		1,01		
3		1,03		
10	Mechanical strength + Temperature conditioned	0,98	FFP1≤ 20% FFP2≤ 6% FFP3≤ 1%	Passed filtering half masks fulfil the requirements of the standard EN 149:2001+A1:2009 given in 7.9.2 in range of the first and second protection classes (FFP1, FFP2)
11		0,96		
12		0,90		

Annex HIB-Test Result:

The test results obtained are given in the tables as follows:

No. of Sample	Condition	Penetration of Paraffin Oil Mist in accordance with EN 13274-7:2019 [%] Flow rate 95 l/min	Requirements in accordance with EN 149:2001+Al:2009	Assessment of Test Result Conformity / Nonconformity
39	As received	1,88	FFP1 ≤ 20 % FFP2 ≤ 6 % FFP3 ≤ 1 %	Passed filtering half masks fulfil the requirements of the standard EN 149:2001+Al :2009 given in 7.9.2 in range of the first and second protection classes (FFP1, FFP2)
40		2,03		
41		1,93		
4	Simulated wearing treatment	1,95	FFP1 ≤ 20 % FFP2 ≤ 6 % FFP3 ≤ 1 %	Passed filtering half masks fulfil the requirements of the standard EN 149:2001+Al :2009 given in 7.9.2 in range of the first and second protection classes (FFP1, FFP2)
5		1,99		
6		1,96		
13	Mechanical strength + Temperature conditioned	1,97	FFP1 ≤ 20 % FFP2 ≤ 6 % FFP3 ≤ 1 %	Passed filtering half masks fulfil the requirements of the standard EN 149:2001+Al :2009 given in 7.9.2 in range of the first and second protection classes (FFP1, FFP2)
14		2,01		
15		1,99		

7.10 COMPATIBILITY WITH SKIN (EN 149:2001 + A1:2009 clause 8.4, 8.5)

Test Method: Described in Clause 8.4 and 8.5.

REQUIREMENT	RESULTS	COMMENT
Materials that may come into contact with the wearer's skin shall not be known to be likely to cause irritation or any other adverse effect to health.	Pass	No irritation or any other adverse effect to health or sensitivity reported by the subjects during the practical performance and TIL tests.

7.11 FLAMMABILITY (EN 149:2001 + A1:2009 clause 8.6)

Test Method: Described in Clause 8.6

REQUIREMENT	RESULTS	COMMENT
The material used shall not present a danger for the wearer and shall not be of highly flammable nature. When tested, the particle filtering half mask shall not bum or not to continue to bum 5s after removal from the flame.	Pass	Detail refer to Annex IV

Annex IV - Test Result: The test results obtained are given in the tables as follows:-

No. of Sample	Condition	Visual inspection	Requirements in accordance with EN 149:2001+A1:2009	Assessment of Test Result Conformity / Nonconformity
45	As received	0,0 s	Filtering half mask shall not bum or not continue to burn for more than 5 s after removal from the flame	Passed
46		0,0 s		
21	Temperature conditioned	0,0 s	Filtering half masks fulfil requirements of the standard EN 149:2001 + A1:2009 given in 7.1 I	Detail refer to Annex IV
22		0,1 s		

7.12 CARBON DIOXIDE CONTENT OF THE INHALATION AIR (EN 149:2001 + A1:2009 clause 8.7)

Test Method: Described in Clause 8.7

REQUIEREMENT	RESULTS	COMMENT
The carbon dioxide content of the inhalation air (dead space) shall not exceed an average of 1.0 % (by volume)	Pass	Detail refer to Annex V

Annex V-Test Result: The test results obtained are given in the tables as follows:

No. of Sample	Condition	CO2 content of the inhalation air (%) by volume	An average CO2 content of the inhalation air (%) by volume	Requirements in accordance with EN 149:2001+A1:2009	Assessment of Test Result Conformity / Nonconformity
26	As received	0,45	0,48	CO2 content of the inhalation air shall not exceed an average of 1,0% by volume	Passed Filtering half masks fulfill requirements of the standard EN 149:2001 + A1:2009 given in 7.12
27		0,52			
28		0,47			

7.13 HEAD HARNESS (EN 149:2001 + A1:2009 clause 8.4, 8.5)

Test Method: Described in Clause 8.4, 8.5

REQUIREMENT	RESULTS	COMMENT
The head harness shall be designed so that the particle filtering half-mask can be donned and removed easily.	Pass	No problem with the head harness reported by the wearers during the practical performance test.
The head harness shall be adjustable or self-adjusting and shall be sufficiently robust to hold the particle filtering half mask firmly in position and capable of maintaining total inward leakage requirements for the device.	Pass	No problem with the head harness reported by the wearers during the practical performance test.

7.14 FIELD OF VISION (EN 149:2001 + A1:2009 clause 8.4)

Test Method: Described in Clause 8.4

REO_UIREMENT	RESULTS	COMMENT
The field of vision is acceptable if determined so in practical performance tests.	PASS	There were no adverse comments following practical performance tests.

7.15 EXHALATION VALVE (EN 149:2001 + A1:2009 clause 8.2, 8.3.4, 8.8, 8.9.1)

Test Method: Clause 8.2. 8.3.4. 8.8. 8.9.1

REQUIREMENT	RESULTS	COMMENT
A particle filtering half mask may have one or more exhalation valve(s). which shall function correctly in all orientations.	N/A	No exhalation valve in tested samples.
If an exhalation valve is provided it shall be protected against or be resistant to dirt and mechanical damage and may be shrouded or may include any other device that may be necessary for the particle filtering half mask to comply with 7.9	N/A	No exhalation valve in tested samples.
Exhalation valve(s), if fitted shall continue to operate correctly after a continuous exhalation flow of 300 l/min over a period of 30s.	N/A	No exhalation valve in tested samples.
When the exhalation valve housing is attached to the face blank. it shall withstand axially a tensile force of 10N applied for 10s.	N/A	No exhalation valve in tested samples.

7.16 BREATHING RESISTANCE (EN 149:2001 + A1:2009 clause 8.9)

Test Method: Described in Clause 8.9

REQUIREMEN			RESULTS	COMMENT
Classification	Max permitted resistance (mbar)			
	Inhalation	Exhalation		
	30 l/min	95 l/min	160 l/min	
FFP1	0,6	2,1	3,0	
FFP2	0,7	2,4	3,0	
FFP3	1,0	3,0	3,0	

Annex VIA-Test Result:

The test results obtained are given in the tables as follows:

No. of Sample	Condition	Inhalation Resistance mbar)									
		Flow rate 30 l/min [mbar]	Requirements in accordance with EN 149:2001+A1:2009	Flow rate 95 l/min [mbar]	Requirements in accordance with EN 149:2001+A1:2009	Assessment of Test Result Conformity / Nonconformity					
42	As received	0.50	FFP1 ≤ 0.60	1.34	FFP1 ≤ 2.10	Passed Qualifies FFP1, FFP2, FFP3					
43		0.53		1.37							
44		0.49		1.37							
7	Simulated wearing treatment	0.52	FFP2 ≤ 0.70	1.40	FFP2 ≤ 2.40						
8		0.50		1.39							
9		0.51		1.41							
23	Temperature conditioned	0.49	FFP3 ≤ 1.0	1.36	FFP3 ≤ 3.00						
24		0.50		1.38							
25		0.49		1.37							
	Exhalation Resistance										
No. of Sample	Condition	Flow rate	Facing directly	Facing vertically upwards	Facing vertically downwards	Lying on the left side	Lying on the right side	Requirements in accordance with EN 149:2001+A1:2009	Assessment of Test Result Conformity / Nonconformity		
42	As received	I 60 l/min	1,65	1,69	1,71	1,72	1,74	FFP1 ≤ 3.0	Passed Qualifies FFP1, FFP2, FFP3		
43			1,71	1,71	1,72	1,75	1,78				
44			1,69	1,67	1,70	1,71	1,72				
7	Simulated wearing treatment		1,63	1,68	1,69	1,70	1,75	FFP2 ≤ 3.0			
8			1,68	1,70	1,73	1,74	1,78				
9			1,65	1,72	1,76	1,71	1,73				
23	Temperature conditioned		1,60	1,64	1,68	1,70	1,72	FFP3 ≤ 3.0			
24			1,58	1,65	1,63	1,69	1,73				
25			1,56	1,62	1,65	1,64	1,68				

7.17 CLOGGING (EN 149:2001 + A1:2009 clause 8.9, 8.10)

Test Method: Described in Clause 8.8, 8.10

REQUIREMENT	RESULTS	COMMENT
Valved particle filtering half masks: After clogging the inhalation resistances shall not exceed: FFP1:4mbar, FFP2:5mbar, FFP3:7mbar at 95L/min continuous flow. The exhalation resistance shall not exceed 3mbar at 160L/min continuous flow. Valueless particle filtering half masks: After clogging the inhalation resistances shall not exceed: FFP1:3mbar, FFP2:4mbar, FFP3:5mbar at 95L/min continuous flow	NAs	This is optional test and not desired by client.

7.18 DEMOUNTABLE PARTS (EN 149:2001 + A1:2009 clause 8.2)

Test Method: Described in Clause 8.2

REQUIREMENT	RESULTS	COMMENT
All demountable parts (if fitted) shall be readily connected and secured, where possible by hand	N/A	No demountable part.

Pass	Requirement satisfied.
NCR	Requirement not satisfied. Refer to the "Result details" section for more information.
NAs	Assessment not carried out.
N/A	Requirement not applicable.

Sample Photo



- End of Report -

NB 2163

EU-TYPINTYG FÖR TYPKONTROLL

Intyg nr: 2163-PPE-1795

Andningsskydd, filtrerande halvmasker för skydd mot partiklar, tillverkade av

PASHA HOME ITH. IHR. LTD. ŞTİ.

testas och utvärderas i enlighet med

EN 149:2001 + A1:2009 Andningsskydd - Filtrerande halvmasker
för skydd mot partiklar - Krav, provning, märkning

Baserat på den utförda typkontrollen med utvärdering av testrapporter, teknisk dokumentation enligt förordningen om personlig skyddsutrustning (EU) 2016/425 bilaga 5, godkänns det att produkten uppfyller kraven i förordningen.

Produktdefinition

Halvmask med partikelfilter för engångsbruk för skydd mot fasta och flytande aerosoler, är en hopfällbar typ,
5-skiktad, utan ventil, öronband och justerbar näsbygel.

Varumärke: Pasha Home

Modell: PSH-NRFM001

Klassificering: FFP2 NR

I detta fall får tillverkaren använda det anmeldta organets nummer (2163) och kan anbringa CE-märkningen, som visas nedan, på de produktmodeller i kategori III som anges ovan, med;

-Utfärdande av en lämplig EU-försäkran om överensstämmelse i enlighet med **personlig skyddsutrustning**.
Utrustningsförordning (EU) 2016/425 Bilaga 9.

-Varaktigt framgångsrik prestanda i enlighet med kraven i **förordning (EU) 2016/425 om personlig skyddsutrustning** och harmoniserade standarder, säkerställd genom bedömningar baserade på **bilaga 7 (modul C2) eller bilaga 8 (modul D)** till förordningen senast ett år efter det att serietillverkningen påbörjats.

Detta certifikat utfärdas ursprungligen den **16/12/2020** och kommer att vara giltigt i fem år om det inte sker några ändringar i den relevanta harmoniserade standarden som påverkar de grundläggande hälsos- och säkerhetskraven.



A blue ink signature of the director's name.

Direktör

TEKNISK UTVÄRDERINGSRAPPORT

RAPPORTDATUM / NR: 15.12.2020 / 2163-KKD-1795

Tillverkare: PASHA HOME MED. IHR. LTD. ŞTİ.

Adress: Mahmutbey Mah. Istoc 1. Ada nr: 154-156 Bagcilar / Istanbul TURKEY

Introduktion

Denna rapport är för den ovan angivna tillverkaren och har utarbetats enligt de testresultat som erhållits från ANHUI HONREN GROUP CO LTD, daterad den 13.12.2020 med serienummer 12-2020-T0575, baserat på EN 149: 2001 + A1 : 2009.

standard och den tekniska dokumentationen av den 25 oktober 2020 (revision 00) som tillhandahålls av tillverkaren.

Tillverkarens tekniska dokumentation, riskbedömning mot de grundläggande hälsoskydds kraven och provningsrapporten har utvärderats med avseende på deras förhållande till förordningen om grundläggande krav på personlig skyddsutrustning och befunnits vara lämpliga.

Denna rapport är en bilaga och en integrerad del av det EU-typkontrollintyg som utfärdats till tillverkaren. Provningsresultaten och det utfärdade intyget gäller endast den provade modellen. Den tekniska rapporten består av totalt 6 sidor.

Produktbeskrivning: Enskild partikelfiltrerande halvmask för skydd mot fasta och flytande aerosoler, är en hopfällbar typ, 5-skiktad, utan ventil, öronband och justerbar näsbygel.

Komponent och material:

Komponent	Material I	Betyg:
Yttre skikt	Spunbond-tyg	50 g/m ²
Filterskikt I	Varm luft bomullstyg	60 g/m
Filterskikt II	Smärtlblåst tyg	25 g/m
Inre skikt	Spunbond-tyg	30 g/ m
Öronband	Spandex + Nylon	Bredd 5+-1 mm Längd: 200+20 mm
Näsbyrgga	Polypropen + galvaniserad järntråd	Bredd 5+-1 mm Diameter: 0,5 +/-0,02 mm

Klassificering: FFP2 NR

Varumärke: Pasha Home **Modell:** PSH-NRFM001



ESSENTIAL HEALTH och
KRAV SOM ANGES I EUROPEISKA UNIONENS FÖRORDNING EU 2016/425 MOTSVARANDE RISKER FÖR
PRODUKTEN

SÄKERHET

1.1. Principer för utformning

1.1.1. Ergonomi

Personlig skyddsutrustning ska vara utformad och tillverkad så att användaren under de förutsebara användningsförhållanden för vilka den är avsedd kan utföra den riskrelaterade verksamheten normalt och samtidigt åtnjuta ett lämpligt skydd på högsta möjliga nivå.

1.1.2. Skyddsnivåer och skyddsklasser

1.1.2.1. Högsta möjliga skyddsnivå

Den optimala skyddsnivån som ska beaktas vid utformningen är den nivå över vilken begränsningarna till följd av bärandet av den personliga skyddsutrustningen skulle förhindra en effektiv användning av den under den period då man utsätts för risken eller under det normala utförandet av verksamheten.

1.1.2.2. Skyddsklasser som är lämpliga för olika risknivåer.

Om olika förutsebara användningsförhållanden är sådana att flera nivåer av samma risk kan urskiljas, måste lämpliga skyddsklasser beaktas vid utformningen av personlig skyddsutrustning.

1.2. Oskuldsfullhet i fråga om personlig skyddsutrustning

1.2.1. Avsaknad av risker och andra inneboende olägenheter.

Personlig skyddsutrustning måste vara utformad och tillverkad så att risker och andra olägenheter inte uppstår under förutsebara användningsvillkor.

1.2.1.1. Lämpliga material för sammansättning

De material som den personliga skyddsutrustningen är tillverkad av, inklusive eventuella nedbrytningsprodukter, får inte påverka användarnas hälsa eller säkerhet negativt.

1.2.1.2. Tillfredsställande ytskick på alla delar av den personliga skyddsutrustningen som kommer i kontakt med användaren.

Alla delar av den personliga skyddsutrustningen som kommer i kontakt eller kan komma i kontakt med användaren när den personliga skyddsutrustningen bärts ska vara fria från ojämna ytor, skarpa kanter, vassa spetsar och liknande som kan orsaka överdriven irritation eller skador.

1.2.1.3. Högsta tillåtna användarhinder

Eventuella hinder som orsakas av personlig skyddsutrustning för de rörelser som ska utföras, de ställningar som ska intas och den sensoriska uppfattningen ska minimeras.

1.3. Bekvämlighet och effektivitet

1.3.1. Anpassning av personlig skyddsutrustning till användarens morfologi

Personlig skyddsutrustning ska utformas och tillverkas så att den kan placeras korrekt på användaren och förbli på plats under den tid som kan förutses, med hänsyn till omgivande faktorer, de åtgärder som ska utföras och de arbetsställningar som ska intas. I detta syfte måste det vara möjligt att anpassa den personliga skyddsutrustningen till användarens morfologi på alla lämpliga sätt, t.ex. genom lämpliga system för justering och fastsättning eller genom att tillhandahålla ett tillräckligt antal olika storlekar.

1.3.2. Lättethet och designstyrka

Personlig skyddsutrustning ska vara så lätt som möjligt utan att det påverkar konstruktionens styrka och effektivitet.

Förutom de särskilda krav som de måste uppfylla för att ge ett adekvat skydd mot riskerna i fråga (se punkt 3), måste personlig skyddsutrustning kunna motstå effekterna av de omgivande fenomen som är inneboende under de förutsebara

användningsförhållandena.

1.4. Information från tillverkaren

De anteckningar som ska upprättas av den tidigare tillverkaren och som ska lämnas när personlig skyddsutrustning släpps ut på marknaden ska innehålla all relevant information om följande:

- a) Utöver namn och adress för tillverkaren och/eller dennes representant i gemenskapen skall följande uppgifter lämnas
 - b) Förvaring, användning, rengöring, underhåll, service och desinfektion. rengöring, underhåll eller desinfektionsskydd som rekommenderas av tillverkarna får inte ha någon negativ inverkan på PPE eller användare när de används i enlighet med relevanta instruktioner:
 - c) Prestanda som registreras vid tekniska tester för att kontrollera de skyddsnivåer eller skyddsklasser som den berörda personliga skyddsutrustningen ger;
 - d) Lämpliga PPE-tillbehör och lämpliga reservdelars egenskaper;
 - e) De skyddsklasser som är lämpliga för olika risknivåer och motsvarande användningsgränser;
 - f) Föräldringstiden eller perioden för föräldrande av materiella anläggningstillgångar eller vissa av deras komponenter;
 - g) Typ av förpackning som lämpar sig för transport;
 - h) Betydelsen av eventuella markeringar (se 2.12).
 - i) I förekommande fall hänvisningar till de direktiv som tillämpas i enlighet med artikel 5.6 b;
 - j) Namn, adress och identifikationsnummer för det anmälda organet som har medverkat vid konstruktionen av personlig skyddsutrustning.
- Dessa noter, som ska vara exakta och begripliga, ska åtminstone finnas på det officiella språket eller de officiella språken i destinationsmedlemsstaten.



2. YTTERLIGARE KRAV SOM ÄR GEMENSAMMA FÖR FLERA KLASSER ELLER TYPER AV PPE

2.1. Personlig skyddsutrustning med justeringssystem

Om personlig skyddsutrustning innehåller justeringsanordningar ska dessa vara konstruerade och tillverkade så att de inte kan lossna oavsiktligt efter justering under förutsebara användningsförhållanden.

2.3. PPE för ansiktet, ögonen och andningsorganen

Eventuell begränsning av användarens ansikte, ögon, synfält eller andningssystem genom personlig skyddsutrustning ska minimeras.

Skärmarna för dessa typer av personlig skyddsutrustning ska ha en optisk neutralitet som är förenlig med användarens precision och varaktighet.

Om det är nödvändigt ska sådan personlig skyddsutrustning behandlas eller förses med medel för att förhindra att den sprutas upp.

De modeller av personlig skyddsutrustning som är avsedda för användare som behöver synkorrigering måste vara kompatibla med glasögon eller kontaktlinser.

2.4. PPE som åldras

Om det är känt att den nya personliga skyddsutrustningens konstruktionsmässiga prestanda kan påverkas avsevärt av åldrande, ska månad och år för tillverkningen och/eller, om möjligt, månad och år för föräldrande märkas outplånit och otvetydigt på varje personlig skyddsutrustning som släpps ut på marknaden och på dess förpackning.

Om tillverkaren inte kan lämna något åtagande om den personliga skyddsutrustningens livslängd ska tillverkarens anvisningar innehålla all information som är nödvändig för att köparen eller användaren ska kunna fastställa en rimlig föräldringsmånad och ett rimligt föräldringsår, med hänsyn till modellens kvalitetsnivå och de faktiska förhållandena vid förvaring, användning, rengöring, service och underhåll.

Om det är troligt att en märkbar och snabb försämring av PPE:s prestanda kan orsakas av åldrande till följd av regelbunden användning av en rengöringsprocess som rekommenderas tillverkaren, ska denne om möjligt anbringa en märkning på varje PPE som släpps ut på marknaden som anger det maximala antal rengöringar som får utföras innan utrustningen måste inspekteras eller kasseras. Om en sådan märkning inte finns ska tillverkaren ange denna information i sina anvisningar.

2.6. Personlig skyddsutrustning för användning i explosionsfarliga omgivningar

Personlig skyddsutrustning som är avsedd för användning i explosionsfarliga omgivningar ska vara konstruerad och tillverkad på ett sådant sätt att den inte kan vara källa till en elektrisk, elektrostatisk eller stötinducerad båge eller gnista som kan orsaka antändning av en explosiv blandning.

2.8. PPE för ingripanden i mycket farliga situationer

De anvisningar som tillverkaren tillhandahåller tillsammans med personlig skyddsutrustning för ingripande i mycket farliga situationer ska särskilt innehålla uppgifter som är avsedda för kompetenta, utbildade personer som är kvalificerade att tolka dem och se till att de tillämpas av användaren.

I instruktionerna ska det också beskrivas hur man ska gå tillväga för att kontrollera att den personliga skyddsutrustningen är korrekt inställd och fungerar när den bär av användaren. Om den personliga skyddsutrustningen har ett larm som aktiveras när den normala skyddsnivån saknas, ska larmet vara konstruerat och placerat på ett sådant sätt att det kan uppfattas av användaren under de förutsebara användningsförhållandena.

2.9. Personlig skyddsutrustning med delar som kan justeras eller tas bort av användaren.

Om personlig skyddsutrustning innehåller komponenter som kan fästas, justeras eller tas bort av användaren för att bytas ut ska dessa komponenter vara utformade och tillverkade så att de lätt kan fästas, justeras och tas bort utan verktyg.

2.12. Personlig skyddsutrustning som är försedd med ett eller flera identifierings- eller igenkänningssärkten som direkt eller indirekt har samband med hälsa och säkerhet.

De identifierings- eller igenkänningsmärken som direkt eller indirekt rör hälsa och säkerhet och som är anbringade på dessa typer eller klasser av personlig skyddsutrustning skall förträdesvis ha formen av harmoniserade pictogram eller ideogram och skall förbli fullt läsbara under den personliga skyddsutrustningens förutsebara användningstid. Dessutom skall dessa märken vara fullständiga, exakta och begripliga för att förhindra varje misstolkning; särskilt om märkena innehåller ord eller meningar skall dessa vara skrivna på det officiella språket eller de officiella språken i den medlemsstat där utrustningen skall användas.

Om den personliga skyddsutrustningen (eller en del av den personliga skyddsutrustningen) är för liten för att en del av den nödvändiga märkningen ska kunna anbringas, ska den relevanta informationen anges på förpackningen och i tillverkarens anteckningar.

3. YTTERLIGARE KRAV SOM ÄR SPECIFIKA FÖR SÄRSKILDA RISKER.

3.10.1. Andningsskydd

Personlig skyddsutrustning som är avsedd att skydda andningsorganen ska göra det möjligt att förse användaren med andningsluft när denne utsätts för en förenad atmosfär och/eller en atmosfär med otillräcklig syrekoncentration.

Den andningsluft som användaren får genom personlig skyddsutrustning måste erhållas på lämpligt sätt, t.ex. genom filtrering av den förenade luften genom personlig skyddsutrustning eller genom tillförsel från en extern, icke-förenad källa.

Materialen och andra komponenter i dessa typer av personlig skyddsutrustning ska väljas eller utformas och införlivas så att de säkerställer en lämplig andning och andningshygien för användaren under den aktuella bärperioden och under de förutsebara användningsförhållandena.

Anskiktsskyddets täthet och tryckfallet vid inandning och, när det gäller filtreringsanordningar, reningskapaciteten måste hålla inträngningen av föroreningar från en förenad atmosfär tillräckligt låg för att inte skada användarens hälsa eller hygien.

Den personliga skyddsutrustningen ska innehålla uppgifter om utrustningens särskilda egenskaper som tillsammans med instruktionerna gör det möjligt för en utbildad och kvalificerad användare att använda den personliga skyddsutrustningen på rätt sätt.

När det gäller filtreringsutrustning skall tillverkarens anvisningar även ange tidsgränsen för lagring av nya originalförpackning.




T e c h n i k a l a s s e s s m e n t e r i n g e n a v s t a n d e r n e n EN 149: 2001 + A1 : 2009 o c h a n d r a s t a n d e r s o m d e n h ä n v i s a r t i l l , k l a u s u l e r s o m m o t s v a r a r (E U) 2016/425-d i r e k t i v e t

Överensstämmer med EN 149:2001 + A1:2009 Standardkrav			
Artikel 5	Klassificering: Partikelfiltrering halvmask Den mask som är föremål för utvärdering på grundval av de testresultat och den tekniska dokumentation som tillhandahålls av tillverkaren klassificeras som: Filtreringseffektivitet och maximalt totalt inkommande läckage - klassificerad som FFP2. Masken är klassificerad för användning i ett skift NR		
Artikel 7.4	Förpackning: Partikelfiltrerande halvmasker förpackas för att skydda dem från kontaminerings före användning och i kartonger för att förhindra mekanisk skada. Förpackningens utformning och produkten anses tåla den förutsebara användningsförhållandena på grundval av de visuella inspekionsresultat som anges i provningsrapporten.		
Artikel 7.5	Material: Material: Material som används i partikelfiltrerande halvmasker, i enlighet med resultaten av simulerad behandling och temperaturkonditionering; Det är underförstått att den klarar hantering och slitage under den period som den partikelfiltrerande halvmasken är avsedd att användas, att den har drabbats av mekaniskt fel på ansiktsdelen eller remmarna, att material från filtermediet frigörs av luftflödet genom filtret och att det inte har utgjort någon fara eller olägenhet för bäraren. Tillverkaren förklarar att de material som används vid tillverkningen av masken inte har någon negativ inverkan på användarnas hälsa och säkerhet. Testresultatet visar att maskerna inte kollapsade när de utsattes för simulerad användning och temperaturkonditionering. Inga besvärliga situationer har rapporterats under de praktiska testerna som utförts av försökspersoner.		
Artikel 7.6	Rengöring och desinfektion: Halvmasken med partikelfilter är inte utformad för att kunna återanvändas. Tillverkaren tillhandahåller inget rengörings- eller desinfektionsförfarande.		
Artikel 7.7	Praktisk prestanda: Testrapporten visar att de mänskliga försökspersonerna inte hade några svårigheter att utföra övningarna när de bar provmaskerna, vid gångtest eller arbetsimulerings-test. Bärarna rapporterade inte om något fel i fråga om huvudbälte/remmar/öronslingor, komfort, fästningarnas säkerhet och synfältet. Inte heller brister som rapporterats under de totala inåtriktade testerna om komfort, synfält och fästproblem.		
	Utvärderade delar	Positivt	Negativ
	2. Komfort för huvudet i selen	2	0
	3. Säkerheten för fästanordningar	2	0
	5. Synfält	2	0
	Krav enligt EN 149:2001 + A1:2009 och Resultat		
	Positiva resultat från testpersonerna Inga brister		

	Villkor: (A.R.) As Received, original.																																																		
Artikel 7.8	Slutbehandling av delarna: Partikelfiltrerande halvmasker, som sannolikt kommer i kontakt med användaren, får inte ha skarpa kanter och inte innehålla grader.																																																		
Artikel 7.9.1	<p>Totalt läckage inåt: Testet för totalt inåtriktat läckage utförs av 10 personer i en aerosolkammare med ett gångband och prover tas under utförandet av de övningar som definieras i standarden. De prover som används i testet utsätts för den konditionering som krävs i standarden som temperaturkonditionering, och som de tas emot. Försökpersonernas ansiktsmått rapporteras också. Mätningsdetaljerna för varje försöksperson och för varje övning finns i däckprovningsrapporten.</p> <p>Det rapporterades att:</p> <p>Alla 50 övningsmätningar är mindre än eller lika med 11 % och värdena varierar mellan 7,23 % och 7,98 %.</p> <p>Alla 10 individers aritmetiska medelvärde är mindre än eller lika med 8 % och värdena varierar mellan 7,58 % och 7,72 %.</p>																																																		
Artikel 7.9.2	<p>Penetrering av filtermaterial: Testning av natriumklorid</p> <table border="1"> <thead> <tr> <th>Villkor</th> <th>Antal prov</th> <th>Testning av natriumklorid 95L/min max (%)</th> <th>Krav i enlighet med EN 149: 2001 +A1:2009</th> <th>Resultat</th> </tr> </thead> <tbody> <tr> <td>(A.R.)</td> <td>36</td> <td>0,86</td> <td></td> <td>Filtrerande halvmasker uppfyller kraven i standarden EN 149:2001 + A1:2009.</td> </tr> <tr> <td>(A.R.)</td> <td>37</td> <td>1,05</td> <td>FFP1 20 %.</td> <td></td> </tr> <tr> <td>(A.R.)</td> <td>38</td> <td>0,95</td> <td>FFP2 6%</td> <td></td> </tr> <tr> <td>(S.W.)</td> <td>1</td> <td>0,99</td> <td>FFP3 1%</td> <td></td> </tr> <tr> <td>(S.W.)</td> <td>2</td> <td>1,01</td> <td></td> <td>som anges i 7.9.2 inom intervallet för klasserna FFP1 och FFP2.</td> </tr> <tr> <td>(S.W.)</td> <td>3</td> <td>1,03</td> <td></td> <td></td> </tr> <tr> <td>(M.S.T.C.)</td> <td>10</td> <td>0,98</td> <td></td> <td></td> </tr> <tr> <td>(M.S.T.C.)</td> <td>11</td> <td>0,96</td> <td></td> <td></td> </tr> <tr> <td>(M.S.T.C.)</td> <td>12</td> <td>0,90</td> <td></td> <td></td> </tr> </tbody> </table> <p>Konditionering: (M.S) Mekanisk styrka (T.C.) Temperaturkonditionering (A.R.) I original skick. (S.W.) Simulerad behandling av slitage</p> 	Villkor	Antal prov	Testning av natriumklorid 95L/min max (%)	Krav i enlighet med EN 149: 2001 +A1:2009	Resultat	(A.R.)	36	0,86		Filtrerande halvmasker uppfyller kraven i standarden EN 149:2001 + A1:2009.	(A.R.)	37	1,05	FFP1 20 %.		(A.R.)	38	0,95	FFP2 6%		(S.W.)	1	0,99	FFP3 1%		(S.W.)	2	1,01		som anges i 7.9.2 inom intervallet för klasserna FFP1 och FFP2.	(S.W.)	3	1,03			(M.S.T.C.)	10	0,98			(M.S.T.C.)	11	0,96			(M.S.T.C.)	12	0,90		
Villkor	Antal prov	Testning av natriumklorid 95L/min max (%)	Krav i enlighet med EN 149: 2001 +A1:2009	Resultat																																															
(A.R.)	36	0,86		Filtrerande halvmasker uppfyller kraven i standarden EN 149:2001 + A1:2009.																																															
(A.R.)	37	1,05	FFP1 20 %.																																																
(A.R.)	38	0,95	FFP2 6%																																																
(S.W.)	1	0,99	FFP3 1%																																																
(S.W.)	2	1,01		som anges i 7.9.2 inom intervallet för klasserna FFP1 och FFP2.																																															
(S.W.)	3	1,03																																																	
(M.S.T.C.)	10	0,98																																																	
(M.S.T.C.)	11	0,96																																																	
(M.S.T.C.)	12	0,90																																																	
Artikel 7.9.2	<p>Penetrering av filtermaterial: Paraffinoljetest</p> <table border="1"> <thead> <tr> <th>Villkor</th> <th>Antal prov</th> <th>Paraffinolja Testning 95L/min max (%)</th> <th>Krav i enlighet med EN 149: 2001 +A1:2009</th> <th>Resultat</th> </tr> </thead> <tbody> <tr> <td>(A.R.)</td> <td>39</td> <td>1,88</td> <td></td> <td>Filtrerande halvmasker uppfyller kraven i standarden EN 149:2001 + A1:2009.</td> </tr> <tr> <td>(A.R.)</td> <td>40</td> <td>2,03</td> <td>FFP1 20 %.</td> <td></td> </tr> <tr> <td>(A.R.)</td> <td>41</td> <td>1,93</td> <td>FFP2 6%</td> <td></td> </tr> <tr> <td>(S.W.)</td> <td>4</td> <td>1,95</td> <td>FFP3 1%</td> <td></td> </tr> <tr> <td>(S.W.)</td> <td>5</td> <td>1,99</td> <td></td> <td>enligt 7.9.2. inom intervallet för klasserna FFP1 och FFP2.</td> </tr> <tr> <td>(S.W.)</td> <td>6</td> <td>1,96</td> <td></td> <td></td> </tr> <tr> <td>(M.S.T.C.)</td> <td>13</td> <td>1,97</td> <td></td> <td></td> </tr> <tr> <td>(M.S.T.C.)</td> <td>14</td> <td>2,01</td> <td></td> <td></td> </tr> <tr> <td>(M.S.T.C.)</td> <td>15</td> <td>1,99</td> <td></td> <td></td> </tr> </tbody> </table> <p>Konditionering: (M.S.) Mekanisk styrka (T.C.) Temperaturkonditionering (A.R.) I befintlig skick, original. (S.W.) Simulerad behandling av slitage</p>	Villkor	Antal prov	Paraffinolja Testning 95L/min max (%)	Krav i enlighet med EN 149: 2001 +A1:2009	Resultat	(A.R.)	39	1,88		Filtrerande halvmasker uppfyller kraven i standarden EN 149:2001 + A1:2009.	(A.R.)	40	2,03	FFP1 20 %.		(A.R.)	41	1,93	FFP2 6%		(S.W.)	4	1,95	FFP3 1%		(S.W.)	5	1,99		enligt 7.9.2. inom intervallet för klasserna FFP1 och FFP2.	(S.W.)	6	1,96			(M.S.T.C.)	13	1,97			(M.S.T.C.)	14	2,01			(M.S.T.C.)	15	1,99		
Villkor	Antal prov	Paraffinolja Testning 95L/min max (%)	Krav i enlighet med EN 149: 2001 +A1:2009	Resultat																																															
(A.R.)	39	1,88		Filtrerande halvmasker uppfyller kraven i standarden EN 149:2001 + A1:2009.																																															
(A.R.)	40	2,03	FFP1 20 %.																																																
(A.R.)	41	1,93	FFP2 6%																																																
(S.W.)	4	1,95	FFP3 1%																																																
(S.W.)	5	1,99		enligt 7.9.2. inom intervallet för klasserna FFP1 och FFP2.																																															
(S.W.)	6	1,96																																																	
(M.S.T.C.)	13	1,97																																																	
(M.S.T.C.)	14	2,01																																																	
(M.S.T.C.)	15	1,99																																																	
Artikel 7.10	Kompatibilitet med huden: I Practical Performance-rapporten rapporterades inte sannolikheten för att maskmaterial i kontakt med huden skulle orsaka irritation eller andra negativa effekter på hälsan.																																																		
Artikel 7.11	<p>Briinnerförlighet</p> <table border="1"> <thead> <tr> <th></th> <th>Antal prov</th> <th>Visuell inspektion</th> <th>Krav i enlighet med EN 149: 2001 +A1:2009</th> <th>Resultat</th> </tr> </thead> <tbody> <tr> <td>(A.R.)</td> <td>45</td> <td>Brinner i 0,0s</td> <td></td> <td>Filtrerande halvmasker uppfyller kraven i standarden EN 149:2001 + A1:2009.</td> </tr> <tr> <td>(A.R.)</td> <td>46</td> <td>Brinner i 0,0s</td> <td></td> <td></td> </tr> <tr> <td>(T.C.)</td> <td>21</td> <td>Brinner i 0,0s</td> <td></td> <td></td> </tr> <tr> <td>(T.C.)</td> <td>22</td> <td>Brinner i 0,1s</td> <td></td> <td></td> </tr> </tbody> </table> <p>Villkor: (A.R.) I befintlig skick, original. (T.C.) Temperaturkonditionering</p>		Antal prov	Visuell inspektion	Krav i enlighet med EN 149: 2001 +A1:2009	Resultat	(A.R.)	45	Brinner i 0,0s		Filtrerande halvmasker uppfyller kraven i standarden EN 149:2001 + A1:2009.	(A.R.)	46	Brinner i 0,0s			(T.C.)	21	Brinner i 0,0s			(T.C.)	22	Brinner i 0,1s																											
	Antal prov	Visuell inspektion	Krav i enlighet med EN 149: 2001 +A1:2009	Resultat																																															
(A.R.)	45	Brinner i 0,0s		Filtrerande halvmasker uppfyller kraven i standarden EN 149:2001 + A1:2009.																																															
(A.R.)	46	Brinner i 0,0s																																																	
(T.C.)	21	Brinner i 0,0s																																																	
(T.C.)	22	Brinner i 0,1s																																																	
Artikel 7.12	<p>Koldioxidhalten i inandningsluften (%) i volymprocent.</p> <table border="1"> <thead> <tr> <th>Villkor</th> <th>Antal prov</th> <th>Koldioxidhalten i inandningsluften (%) i volymprocent.</th> <th>En genomsnittlig CO2-halt i inandningsluften</th> <th>Krav enligt EN 149: 2001 +A1:2009</th> <th>Resultat</th> </tr> </thead> <tbody> <tr> <td>(A.R.)</td> <td>26</td> <td>0,45</td> <td></td> <td></td> <td></td> </tr> <tr> <td>(A.R.)</td> <td>27</td> <td>0,52</td> <td></td> <td></td> <td></td> </tr> <tr> <td>(A.R.)</td> <td>28</td> <td>0,47</td> <td>0,48 (%)</td> <td>CO2-innehållet i Inandningsluften. får inte överstiga ett genomsnitt av 1,0 % av volymen</td> <td>Godkänd Filtrering av halva masker uppfyller kraven i standarden.</td> </tr> </tbody> </table> <p>Villkor: (A.R.) I befintlig skick, original.</p>	Villkor	Antal prov	Koldioxidhalten i inandningsluften (%) i volymprocent.	En genomsnittlig CO2-halt i inandningsluften	Krav enligt EN 149: 2001 +A1:2009	Resultat	(A.R.)	26	0,45				(A.R.)	27	0,52				(A.R.)	28	0,47	0,48 (%)	CO2-innehållet i Inandningsluften. får inte överstiga ett genomsnitt av 1,0 % av volymen	Godkänd Filtrering av halva masker uppfyller kraven i standarden.																										
Villkor	Antal prov	Koldioxidhalten i inandningsluften (%) i volymprocent.	En genomsnittlig CO2-halt i inandningsluften	Krav enligt EN 149: 2001 +A1:2009	Resultat																																														
(A.R.)	26	0,45																																																	
(A.R.)	27	0,52																																																	
(A.R.)	28	0,47	0,48 (%)	CO2-innehållet i Inandningsluften. får inte överstiga ett genomsnitt av 1,0 % av volymen	Godkänd Filtrering av halva masker uppfyller kraven i standarden.																																														

Artikel 7.13	Huvudbälte: I testrapporterna om praktisk prestanda och TIL har inga negativa effekter rapporterats för påtagning och avtagning av masken. Resultaten av dessa tester visar också att öronslingorna/huvudbältet klarar av att hålla masken tillräckligt stadigt.
Artikel 7.14	Synfält: I rapporten Practical Performance rapporterades inga negativa effekter för synfältet när masken bärts.
Artikel 7.15	Utandningsventil(er): Den modell som inspekteras har inga ventiler. Godkänd.
Artikel 7.16	Andningsmotstånd: inandning Den övergripande utvärderingen i de siffror som samlats in för 9 olika prover 3 som mottagits. 3 med temperaturkonditionering och 3 med simulerad slitagebehandling som är konditionerade överensstämmer med de gränsvärden som anges i standarden för klasserna FFP1, FFP2 och PFP3. Detta gäller för inandningsresultat för 30 L/min, 95 L/min och utandning vid 160 L/min. Godkänd.



Artikel 7.17	Tillämpning: Detta test tillämpas inte på halvmasken med partikelfilter som inte kan återanvändas. (För anordningar som används i ett enda skift är provet för igensättning ett valfritt prov. För återanvändbara anordningar är testet obligatoriskt.)
Artikel 7.18	Delar som kan demonteras: Det finns inga demonterbara delar på produkten.
Artikel 8	Testning: Alla provningar som utförs i enlighet med punkt 8 i denna standard finns tillgängliga i provningsrapporten och utvärderas i denna rapport för kvalificering och klassificering av masken.
Artikel 9	Märkning - Förpackning: Nödvändiga märkningar finns på produktförpackningen (lädan). Tillverkarens namn och varumärke är tydligt synligt. Maskens typ och klassificering, inklusive status för återanvändbarhet, hänvisning till standarden EN 149:2001 +A1:2009, är då hållbarhetstiden löper ut, bruks- och förvaringsanvisningar, pictogram och CE-märkning finns på produktförpackningen. Utvärderingen ovan grundar sig på det tekniska dokumentet för förpackning och märkning, för lädans utformning. Kontrollerat avsnitt 9.1 i det tekniska dokumentet. Den tekniska dokumentationen för maskkonstruktion (ritning) utvärderades också med avseende på märkningskrav, ritning PSH-NRFM001. Masken ska märkas med information om tillverkarens varumärke (Pasha Home), masktyp, hänvisning till standarden EN 149+A1:2009 och klassificering, inklusive maskens återanvändbarhet. Tillverkaren har också tryckt CE-märkning med vårt nummer som anmält organ. Masken har inga underenheter. De prover som testats av laboratoriet är försedda med nödvändig märkningsinformation enligt vad som anges i den tekniska dokumentationen. tillverkaren ska också följa märkningsinstruktionen i den tekniska dokumentationen för serietillverkning. Ritning för modell PSH-NRFM001 finns i tillverkarens tekniska dokumentation, avsnitt 6.
Artikel 10	Information som ska lämnas av tillverkaren: I var och en av de minsta kommersiellt tillgängliga förpackningarna för produkten definieras genomförande (installationsinstruktioner), kontroller före användning, varnings- och användningsbegränsningar, förvaring och betydelser av symboler/pictogram. Användarinstruktioner i den tekniska dokumentationen, avsnitt 8, har befunnits vara lämpliga. Tillverkaren ska inkludera denna dokumenterade användarinformation i varje minsta kommersiellt tillgängliga förpackning.

PREPARED BY	APPROVED BY
PPE Expert 	Director 

ANHUI HONREN GROUP CO LTD
Xingyuan East Road, Economic Development Zone, Anhui, Kina

TESTRAPPORT

Rapportdatum: 13.12.2020

Rapportnummer: 12-2020-T0575

INFORMATION OM KUNDEN OCH PROVET

TEST ÅGARE	PASHA HOME ITH. IHR. LTD. STI		
ADRESS	Mahmutbey Mah. Istoc 1 Ada No: 154-156 Bagcilar / Istanbul TURKEY		
EXEMPEL PÅ EN BESKRIVNING	Skyddsmask av vikbar typ		
VARUMÄRKE - MODELL	PASHA HOME / PSH-NRFM001		
PROVNINGSSTANDARD.	EN 149:2001+A1:2009		
FALLNUMMER	CE-PPE-3749		
DATUM FÖR MOTTAGANDE AV PROVET	23.11.2020	STARTDATUM FÖR TESTNINGEN	23.11.2020
DESINFEKTION INSTRUKTION om tillämpligt	Ej angivet, endast för engångsbruk		
ANTAL PROVER	50	ID:n för proverna:	1-46
I BEFINTLIGT SKICK PROV NR	26-46		
KONDITIONERINGSSAMLIN G NEJ	Simulerad användning behandling	1-2-3-4-4-5-5-6-7-7-8-9 (Som mottagna)	
	Temperatur konditionering	10-11-12-13-14-15 (prov efter provning av mekaniska styrka)	
	Mekanisk styrka	16-17-18-19-20-21-22-23-24-25 (enligt mottagandet)	

De resultat som anges i denna provningsrapport gäller de provade proverna. Rapportens innehåll får inte återskapas delvis utan skriftligt medgivande från ANHUI HONREN GROUP CO LTD.



UNIVERSAL
SERTİFİKASYON
VE GOZETİM HİZM.
TİC. LTD. STİ.
Necip Fazıl Bulvarı, Kevap Sitesi, E2 Blok, No:44/84
Yüksek Dudullu-Ümraniye/İSTANBUL
Telefon: 0216 455 80 80 Faks: 0216 455 80 08
Sarıgazi V.D. 892 025 8722

Suat KAÇMAZ
Director

1. RAPPORTSAMMANFATTNING

TEST STANDARD	TESTNAME	RESULTAT	UTVÄRDERIN G
EN 149:2001 + Al:2009 klausul 8.5 EN 13274-1 :2001	Testning av totalt inkommande läckage	Passa	FFP2
EN 149:2001 + Al:2009 klausul 8.11 EN 13274-7:2019	Penetration av filtermaterial1	Pass a	FFP2
EN 149:2001 + Al:2009 klausul 8.6 EN 13274-4:2001	Testning av brandfarlighet	Passa	Se resultat
EN 149:2001 + Al:2009 klausul 8.7 EN 13274-6:2001	Koldioxidinnehållet i testning av inandningsluften	Pas	Se resultat
EN 149:2001 + Al:2009 klausul 8.9 EN 13274-3:2001	Andning Inandningsmotstånd-30 1/min	Pass a	Se resultat
	Andning Inandning Motstånd-95 1/min	Passa	Se resultat
EN 149:2001 + Al:2009 klausul 8.9 EN 13274-3:2001	Utandningsmotstånd, flödeshastighet 160 1/min	Passa	Se resultat



2. TESTRESULTAT OCH UTVÄRDERING.

7.4 FÖRPACKNING (EN 149:2001 + A1:2009 klausul 8.2)

Testmetod: Kontrollmetod: Klausul 8.2 - Visuell kontroll

KRAV	RESULTAT	KOMMENTAR
Halvmasker med partikelfiltrering skall erbjudas till försäljning i plastsäckar, i större plastsäckar. förförpackas på ett sådant sätt att Pass mot mekaniska skador och användning. föroreningar före användning.	Maskerna var förpackade i förseglade i en stor papplåda somgav dem skydd visst skydd mot mekaniska skadoreller föroreningar före	

Laboratorium A

7.5 MATERIAL (EN 149:2041 + A1:2009 klausul 8.2, 8.3.1, 8.3.2)

Testmetod: Kontrollmetod: Klausul 8.2 - Visuell kontroll

Punkt 8.3.1 - Simulerad slitagebehandling

En andningsmaskin ställs in på 25 cykler/min och 2,0 l/slag. Den partikelfiltrerande halvmasken monterades på ett Sheffield-attraktionshuvud.

För provning används en saturator i utandningsledningen mellan andningsmaskinen och provdockans huvud, och saturatorn ställs in på en temperatur som överstiger 37 °C för att möjliggöra kylnings av luften innan den når provdockans huvudmun.

Luften har mätts vid (37 + 2) °C vid munnen på provdockans huvud Punkt

8.3.2-Temperaturkonditionering

Omgivningstemperaturen för provningen har varit mellan 16 °C och 32 °C och temperaturgränserna har varit med en noggrannhet på +1 °C.

a) under 24 timmar i en torr atmosfär vid (70 + 3) °C;

b) under 24 timmar till en temperatur av (-30 + 3) °C och låta den återgå till rumstemperatur under minst 4 timmar mellan exponeringarna och före efterföljande provning. Konditioneringen har utförts på ett sätt som säkerställer att ingen termisk chock uppstår.

FÖRUTSÄTTNINGAR	RESULTAT	KOMMENTAR
Det material som används ska vara lämpligt för att tåla hantering och slitage under den period som partikelfiltreringen ska användas. Halvmasken är avsedd att användas.	Passa	Det material som användes kunde motstå hantering och slitage under den begränsade laboratorietestning som utfördes.
Eventuellt material från filtermediet som frigörs genom luftflödet genom filtret får inte utgöra en fara eller besvärs för bäraren.	Passa	Den utgjorde ingen fara eller olägenhet för bäraren.
Efter att ha genomgått den konditionering som beskrivs i 8.3.1 får ingen av de partikelfiltrerande halvmaskerna ha drabbats av mekaniskt fel på ansiktsdelen eller remmarna.	Passa	Inget av de konditionerade proverna drabbades av mekaniskt fel.
När det är villkorat i enlighet med 8.3.1 och 8.3.2 Halvmasken för partikelfiltrering får inte kollapsa.	Passa	Inget av proverna hade inte kollapsat efter konditionering.

Laboratorium B

7.6. Rengöring och desinfektion (EN 149:2001 + Al:2009 klausul 8.4, 8.5, 8.11)

<u>FÖRUTSÄTTNINGAR</u>	<u>RESULTAT</u>	<u>KOMMENTAR</u>
Om den partikelfiltrerande halvmasken är utformad för att kunna återanvändas ska de material som används tåla de rengörings- och desinfektionsmedel och förfaranden som tillverkaren anger. Med hänvisning till 7.9.2 ska den återanvändbara partikelfiltrerande halvmasken efter rengöring och desinfektion uppfylla penetrationskravet för den relevanta klassen.	N/A	Denna artikel är inte tillämplig på testad skyddsmask som är en engångsmask för engångsbruk.

Testmetod: Beskrivs i punkterna 8.4, 8.5 och 8.11.

7.7. PRAKTISK PRESTANDA (EN 149:2001 + Al:2009 klausul 8.4)

Testmetod: Beskrivs i punkt 8.4.

<u>FÖRUTSÄTTNINGAR</u>	<u>RESULTAT</u>	<u>KOMMENTAR</u>
Den partikelfiltrerande halvmasken ska genomgå praktiska prestandaprova under realistiska förhållanden. Dessa allmänna provningar syftar till att kontrollera utrustningen för brister som inte kan fastställas genom de provningar som beskrivs på andra ställen i denna standard. Två maskprover som mottagits används av två försökspersoner för testerna av gång (10 minuter gång med en hastighet på 6 km/h) och arbetssimulering (böjd gång, krypning och fyllning av korgar).	Inga brister	För närmare upplysningar hänvisas till bilaga I.

Bilaga I-Testresultat:

Utvärderade delar	Positiv bedömning	Negativ bedömning	Krav i enlighet med EN 149:2001+A1 :2009	Bedömning av testresultatet Överensstämmelse/ickeöverensstämmelse
Ansiktsdelens passform Komfort för huvudbältet Säkerheten i fästet Synfället	2 2 2 2	0 0 0 0	Filtrerande halvmasker får inte ha brister som har att göra med bärarens acceptans.	Filtrering av halvmasker uppfyller kraven i standarden EN 149:2001 + Al:2009 som anges i 7.7. Inga brister

Antal stickprov: 29 (A.R), 30 (A.R)

Försökspersonerna (MEG och MA) kunde slutföra övningarna och rapporterade inga besvär eller problem med masken.

7.8. DELarnas ytbehandling (EN 149:2001 + Al:2009 klausul 8.2)

Testmetod: Beskrivs i punkt 8.2.

<u>FORUTSATNINGAR</u>	<u>RESULTAT</u>	<u>KOMMENTAR</u>
De delar av anordningen som sannolikt kommer i kontakt med bäraren får inte ha några vassa kanter eller grader.	Passa	Ingen av de provkroppar som användes i laboratorietestningen visade tecken på skarpa kanter eller grader vid visuell inspektion och prestandatester.

7.9.1 TOTALT LÄCK INVÄNDIGT LÄCK (EN 149:2001 + A1:2009 klausul 8.5)

Testmetod: Beskrivs i punkt 8.5.

FÖRUTSÄTTNINGAR	RESULTAT	KOMMENTAR
Det totala inåtriktade läckaget består av tre komponenter: läckage från fronttätning, läckage från utandningsvärdet (om utandningsvärdet är monterat) och filterpenetrations. För partikelfiltrerande halvmasker som är monterade enligt tillverkarens information ska minst 46 av 50 individuella resultat inte vara större än: 25 % för FFP1, 11 % för FFP2, 5 % för FFP3 och dessutom ska minst 8 av 10 individuella bärare aritmetiska medelvärden för det totala läckaget inåt inte vara större än: 22 % för FFP1, 8 % för FFP2, 2 % för FFP3.	Passa	Klassificerad som FFP2 För närmare uppgifter se bilaga II.

Bilaga II-Testresultat:

De erhållna provningsresultaten anges i följande tabeller

Testämne	Antal prov	Kondes.	1. Gå (%)	Huvud sida/ sida (%)	Huvudet uppåt/nedåt (%)	Tal (%)	2. Gång (%)	Genomsnitt (%)
1	31	A.R.	7,23	7,41	7,62	7,77	7,89	7,58
2	32	A.R.	7,31	7,52	7,69	7,79	7,96	7,65
3	33	A.R.	7,33	7,54	7,72	7,85	7,94	7,67
4	34	A.R.	7,35	7,55	7,71	7,82	7,93	7,67
5	35	A.R.	7,29	7,53	7,75	7,86	7,91	7,66
6	16	T.C.	7,34	7,60	7,71	7,84	7,95	7,68
7	17	T.C.	7,33	7,57	7,69	7,81	7,97	7,67
8	18	T.C.	7,31	7,60	7,72	7,83	7,95	7,68
9	19	T.C.	7,38	7,62	7,75	7,89	7,98	7,72
10	20	T.C.	7,34	7,63	7,72	7,85	7,92	7,69
Alla 50 individuella träningsresultat var inte högre än 11 %.								Godkänd (FFP2)
Alla tio aritmetiska medelvärden för enskilda bärare var inte större än 8 %.								

Testämne	Längd på ytan (mm)	Bredd på ytan (mm)	Djup på ytan (mm)	Bredd i munnen (mm)
1	117	155	130	60
2	113	148	128	62
3	112	160	134	59
4	115	148	125	61
5	120	158	132	57
6	118	150	134	59
7	115	152	130	57
8	117	155	134	59
9	114	149	128	57
10	110	150	131	55

Endast för kännedom

7.9.2 PENETRATION AV FILTERMATERIAL (EN 149:2001 + A1:2009 klausul 8.11)

Testmetod: Beskrivs i punkt 8.11.

FÖRUTSÄTTNINGAR			RESULTAT	KOMMENTAR
Klassificering	Maximal penetration av testaerosolen NaCl-test 95 l/min % max	Paraffinoljetest 95 l/min % max	Passa	Se bilaga IIIA och bilaga IIIA. IIIB
FFP1	20	20		
FFP2	6	6		
FFP3	1	1		

Bilaga IIIA - Testresultat:

De erhållna provningsresultaten anges i följande tabeller:

Antal prov	Villkor	Penetration av natriumklorid enligt EU 13274-7:2019 (%) Flödeshastighet 95 l/min	Krav i enlighet med EN 149:2001 + A1:2009	Bedömning av testresultatets överensstämmelse/ icke överensstämmelse
36	I befintligt skick	0,86	FFP1 20 %.	Godkänd Filtrerande halvmasker uppfyller kraven i standarden EN 149:2001+A1:2009. som anges i 7.9.2 inom intervallet för den första och andra skyddsklassen (FFP1,FFP2).
37		1,05		
38		0,95		
1	Simulerad behandling av slitage	0,99	FFP2 6%	
2		1,01		
3		1,03		
10	Mekanisk hållfasthet + Temperatur konditionerad	0,98	FFP3 1%	
11		0,96		
12		0,90		

Bilaga HIB-testresultat:

De erhållna provningsresultaten anges i följande tabeller:

Antal Exempel	Villkor	Penetration av paraffinoljedimma i i enlighet med EN 13274-7:2019 [%] Flödes hastighet 95 l/min	Krav i i enlighet med EN 149:2001+Al:2009	Bedömning av testresultatet Överensstämmelse/ickeöverensstämmelse
39	I befintligt skick	1,88	FFP1 20 %	Godkänd filtrerande halvmasker uppfyller kraven i standarden EN 149:2001 +Al :2009 given i 7.9.2 inom intervallet för den första och andra skyddsklassen (FFP1, FFP2).
40		2,03		
41		1,93		
4	Simulerad användning behandling	1,95	FFP2 6 %	
5		1,99		
6		1,96		
13	Mekanisk hållfasthet + Temperatur villkorad	1,97	FFP3 1 %	
14		2,01		
15		1,99		

7.10 KOMPATIBILITET MED HU DEN (EN 149:2001 + AI:2009 klausul 8.4, 8.5)

Testmetod: Beskrivs i punkterna 8.4 och 8.5.

FÖRUTSÄTTNINGAR	RESULTAT	KOMMENTAR
Material som kan komma i kontakt med bärarens hud får inte vara känd för att kunna orsaka irritation eller någon annan negativ inverkan på hälsan.	Passa	Ingen irritation eller någon annan negativ effekt på hälsa eller känslighet rapporterades av försökspersonerna under de praktiska testerna och TIL-testerna.

7.11 BRANDBARHET (EN 149:2001 + AI:2009 klausul 8.6)

Testmetod: Beskrivs i punkt 8.6.

FORUTSATTNINGAR	RESULTAT	KOMMENTAR
Det material som används får inte utgöra en fara för bäraren och får inte vara lättantändligt. Vid provning får den partikelfiltrerande halvmasken inte ge ifrån sig eller fortsätta att ge ifrån sig 5 sekunder efter det att den avlägsnats från lågan.	Passa	För närmare uppgifter se bilaga IV.

Bilaga LV - Testresultat: De erhållna provningsresultaten anges i följande tabeller-.

Antal prov	Villkor	Visuell inspektion	Krav i enlighet med EN 149:2001+AI:2009	Bedömning av testresultatets överensstämmelse/icke överensstämmelse
45	I befintligt skick	0,0 s	Filtrering av halvmasken får inte brinna eller fortsätta att brinna under mer än 5 sekunder efter det att den har avlägsnats från lågan.	Godkänd Filtrerande halvmasker uppfyller kraven i standarden EN 149:2001 + A I :2009 enligt 7.1 I
46		0,0 s		
21	Temperatur konditionerad	0,0 s		
22		0,1 s		

7.12 Koldioxidhalten i inandningsluften (EN 149:2001 + AI:2009 klausul 8.7)

Testmetod: Beskrivs i punkt 8.7.

FÖRUTSÄTTNINGAR	RESULTAT	KOMMENTAR
Koldioxidhalten i inandningsluften (död utrymme) får inte överstiga i genomsnitt 1,0 %. (i volym)	Passa	För närmare uppgifter se bilaga V.

Bilaga V-Testresultat: De erhållna provningsresultaten anges i följande tabeller:

Antal prov	Villkor	CO2-halt i inandningsluften (%) i volymprocent.	En genomsnittlig CO2-halt i inandningsluften (%) i volymprocent.	Krav i enlighet med med EN 149:2001+AI:2009	Bedömning av testresultatets överensstämmelse/icke överensstämmelse
26	I befintligt skick	0,45	0,48	CO2-halten i inandningsluften får inte överstiga i genomsnitt 1,0 volymprocent.	Godkänd Filtrerande halvmasker uppfyller kraven i standarden EN 149:2001 +A I:2009 given i 7.12
27		0,52			
28		0,47			

7.13 HÖKESÄTT (EN 149:2001 + A I:2009 klausul 8.4, 8.5)

Testmetod: Beskrivs i punkt 8.4, 8.5.

FÖRUTSÄTTNINGAR	RESULTAT	KOMMENTAR
Huvudbältet ska vara konstruerat så att Partikelfiltrerande halvmask kan lätt tas på och av.	Passa	Inga problem med huvudbältet rapporterades av bärarna under det praktiska testet.
Huvudbältet ska vara justerbart eller självjusterande, och ska vara tillräckligt robusta för att hålla den partikelfiltrerande halvmasken stadigt på plats och kunna upprätthålla kraven på totalt läckage inåt för anordningen.	Passa	Inga problem med huvudbältet rapporterades av bärarna under det praktiska testet.

7.14 SIKTOMRÅDE (EN 149:2001 + A1:2009 klausul 8.4)

Testmetod: Beskrivs i punkt 8.4.

REO_UIREMENT_____	RESULTAT	KOMMENTAR
Synfältet är godtagbart om det bestäms så i praktiska prestandatester.	PASSA	Det fanns inga negativa kommentarer efter de praktiska testerna.

7.15 UTVÄRMNINGSVENTIL (EN 149:2001 + A1:2009 klausul 8.2, 8.3.4, 8.8, 8.9.1)

Testmetod: Klausul 8.2. 8.3.4. 8.8. 8.9.1

FORUTSATNINGAR	RESULTAT	KOMMENTAR
En partikelfiltrerande halvmask kan ha en eller flera utandningsventiler som ska fungera korrekt i alla riktningar.	N/A	Ingen utandningsventil i de testade proverna.
Om en utandningsventil finns ska den vara vara skyddade mot eller motståndskraftiga mot smuts och mekaniska skador och får vara täckta eller försedda med andra anordningar som kan vara nödvändiga för att Halvmask med partikelfilter för att uppfylla kraven i 7.9.	N/A	Ingen utandningsventil i de testade proverna.
Utandningsventil(er), om de är monterade, ska fortsätta att fungera korrekt efter ett kontinuerligt utandningsflöde på 300 l/min under 30 sekunder.	N/A	Ingen utandningsventil i de testade proverna.
När utandningsventilhöljet är monterat på Den ska motstå en dragkraft på 10N i axial riktning under 10 sekunder.	N/A	Ingen utandningsventil i de testade proverna.

7.16 Andningsmotstånd (EN 149:2001 + A1:2009 klausul 8.9)

Testmetod: Beskrivs i punkt 8.9.

REQUIREMENT				RESULTAT	KOMMENTAR
Klassificering	Max tillåtet motstånd (mbar)				
	Inandning		Utandning		
	30 l/min	95 l/min	160 l/min		
FFP1	0,6	2,1	3,0		
FFP2	0,7	2,4	3,0		
FFP3	1,0	3,0	3,0		
				Pass a	Närmare upplysningar finns i bilaga VIA-VI B.

Bilaga VIA-Testresultat:

De erhållna provningsresultaten anges i följande tabeller:

Antal prov	Villkor	Inandningsmotstånd mbar)					Bedömning av testresultatets överensstämmelse /		
		Flödeshastighet 30 l/min [mbar]	Krav i enlighet med EN 149:2001+A I :2009	Flödeshastighet 95 l/min [mbar]	Krav i enlighet med EN 149:2001+A I :2009				
42	I befintligt skick	0.50	FFP1 0,60 FFP2 0,70 FFP3 1.0	1.34	FFP1 2.10 FFP2 2.40 FFP3 3.00	Godkänd Kvalificerar FFP1, FFP2, FFP3			
43		0.53		1,37					
44		0.49		1.37					
7	Simulerad bär behandling	0.52		1.40					
8		0.50		1.39					
9		0.51		1.41					
23	Temperatur villkorad	0.49		1,36					
24		0,50		1,38					
25		0.49		1.37					
Utandning	Motstånd								
Antal Exemplar	Villkor	Flöde kurs	Inför direkt	Inför vertikalt uppåt	Inför vertikalt nedåt	Ljungande på vänster	Krav i enlighet med EN 149:2001+A1:2009	Bedömning av Testresultat Överensstämm Avvikelse	
42	I befintligt	I 60l/min	1,65	1,69	1,71	1,72	1,74	FFP1 3.0 FFP2 3.0 FFP3 3.0	
43			1,71	1,71	1,72	1,75	1,78		
44			1,69	1,67	1,70	1,71	1,72		
7	Simulerad bär behandling		1,63	1,68	1,69	1,70	1,75		
8			1,68	1,70	1,73	1,74	1,78		
9			1,65	1,72	1,76	1,71	1,73		
23	Temperatur villkorad		1.60	1,64	1,68	1,70	1,72		
24			1,58	1,65	1,63	1,69	1,73		
25			1,56	1,62	1,65	1,64	1,68		

7.17 FÖRSEGLING (EN 149:2001 + A1:2009 c1a användning 8.9, 8.10)

Testmetod: Beskrivs i avsnitt 8.8, 8.10.

FÖRUTSÄTTNINGAR	RESULTAT	KOMMENTAR
Halvmasker med ventiler som filtrerar partiklar: Efter tillämpning får inandningsmotståndet inte överstiga: FFP1:4mbar, FFP2:5mbar, FFP3:7mbar vid 95L/min kontinuerligt flöde. Utandningsmotståndet får inte överstiga 3mbar vid 160L/min kontinuerligt flöde. Värdelösa partikelfiltrerande halvmasker: Efter tillämpning får inandningsmotståndet inte överstiga: FFP1:3mbar, FFP2:4mbar, FFP3:5mbar vid 95L/min kontinuerligt flöde.	NAs	Detta är ett frivilligt test som inte är önskvärt för kunden.

7.18 AVMOBILDANDE DELAR (EN 149:2001 + A1:2009 klausul 8.2)

Testmetod: Beskrivs i punkt 8.2.

REQUIREMENT	RESULTAT	KOMMENTAR
-------------	----------	-----------

Alla demonterbara delar (om de är monterade) ska lätt kunna anslutas och fästas, om möjligt för hand.	N/A	Ingen demonterbar del.
---	-----	------------------------

PassRequirement uppfyllt.

NCRKravet är inte uppfyllt. Se avsnittet "Resultatinformation" för mer information.

NAsBedömnning har inte utförts.

N/ARekvisitet är inte tillämpligt.

ampl foto



- Slut på rapporten -